Worksheet for Technical Review of Working Draft of Proposed Permit

Company Name:	**Bayou Cove Peaking Power LLC**	**AI #:**	**92706**	**TEMPO Activity No:**	**PER20060001**
Facility Name:	**Bayou Cove Peaking Power Plant**	**Remarks Submitted by:**	**Gary Ellender**		
Permit Writer:	**Shane Clary**	**Permit Writer Email address:**	**Shane.Clary@la.gov**		

Instructions

Permit Reference – Indicate specific portion(s) of the permit to which the remark relates (i.e. "Specific Condition 120", or "Section II Air Permit Briefing Sheet", etc.).

Remarks – Explain the basis for each remark. Provide regulatory citations where possible. If the remark is made due to an error or omission in the permit application this must be noted and the revised information ***must be submitted.*** Revised information may be submitted separately from this worksheet. Please be aware that revised information must be submitted in writing and certified by the Responsible Official, and if necessary, by a Professional Engineer licensed in Louisiana. *Please Note:* New or additional equipment, processes or operating conditions not addressed in the original permit application will be addressed on a case-by-case basis. The Department reserves the right to address such changes in a separate permit action.

DEQ Response – ***DO NOT COMPLETE THIS SECTION.*** This section will be completed by Air Permits Division of DEQ, included in the proposed permit package and made available for public review during the public comment period.

- Additional rows may be added as necessary.
- Completed Form shall be emailed to the Permit writer in MS Word compatible format within the deadline specified in the email notification.

Permit Reference	Remarks	Air Permits Division Response (for official use only)
SPECIFIC REQUIREMENTS		
Specific Condition 7	**NOx CEMs are located on each unit. We do not believe it is necessary to determine nitrogen content of the fuel. Request this be dropped, or add language that NOx CEMS will meet the requirement.**	**The language requiring nitrogen content of the fuel to be determined has been removed.**
Specific Conditions 11, 12	**The CT's operate with DLN, no water or steam is injected in these units. These conditions do not apply.**	**Change made.**
Specific Condition 41	**These are peaking units and operate at very low capacity factors. We would like to request an exemption from this test requirement. If required, request that CO testing only be required on 2 of the four units (the four units are identical).**	**CO testing is required for any 2 of the 4 units**