Worksheet for Technical Review of Working Draft of Proposed Permit

Company Name:	**Cajun Sugar Cooperative, Inc.**	**AI #:**	**1481**	**TEMPO Activity No:**	**PER20080001**
Facility Name:	**Cajun Sugar Cooperative, Inc.**	**Remarks Submitted by:**	**Harold Birkett**		
Permit Writer:	**Tommy Menuet**	**Permit Writer Email address:**	**Tommy.menuet@la.gov**		

Instructions

Permit Reference – Indicate specific portion(s) of the permit to which the remark relates (i.e. "Specific Condition 120", or "Section II Air Permits Briefing Sheet", etc.).

Remarks – Explain the basis for each remark. Provide regulatory citations where possible. If the remark is made due to an error or omission in the permit application this must be noted and the revised information ***must be submitted.*** Revised information may be submitted separately from this worksheet. Please be aware that revised information must be submitted in writing and certified by the Responsible Official, and if necessary, by a Professional Engineer licensed in Louisiana. *Please Note:* New or additional equipment, processes or operating conditions not addressed in the original permit application will be addressed on a case-by-case basis. The Department reserves the right to address such changes in a separate permit action.

DEQ Response – ***DO NOT COMPLETE THIS SECTION.*** This section will be completed by Air Permits Division of DEQ, included in the proposed permit package and made available for public review during any required public comment period.

- Additional rows may be added as necessary.
- Completed Form shall be emailed to the Permit writer in MS Word compatible format within the deadline specified in the email notification.
- ***DO NOT USE THIS FORM TO SUBMIT COMMENTS DURING THE OFFICIAL PUBLIC COMMENT PERIOD.***

Permit Reference	Remarks	Air Permits Division Response (for official use only)
Specific Require 22	Change "Sack" to "Stack"	Change made
Specific Require 50	Change "Sack" to "Stack"	Change made
Specific Require 123 and 147	Regards stack testing of Boiler 5 and 6. Boiler tests for both of these boilers are on file. Is this necessary?	LDEQ, Air Permits Division has both Boiler 5 and Boiler 6 emission stack test on file. Stack test requirements for Boiler 5 and Boiler 6 were removed
Specific Requirement 22, 50, 68, 96	Regards stack testing of either Boiler 1 or 2 and either Boiler 3 or 4. These boilers currently do not have stack test ports. As these boilers are of similar design and capacity would testing of one of these 4 boilers suffice?	The heat capacity for Boilers 1 thru 4 heat are almost identical, therefore, stack testing for Boilers 3 or 4 are required and not required for Boilers 1 or 2.
Specific Requirement 158	Could "Fuel usage and NOx emission factor can be used to calculate daily NOx emissions.", be added to clarify?	Similar language was added to this requirement for clarification.