Worksheet for Technical Review of Working Draft of Proposed Permit

Company Name:	LSU Service Station	AI #:	5540	TEMPO Activity No:	PER20070001
Facility Name:	Louisiana State University	Remarks Submitted by:			
Permit Writer:	Sam Phillips	Permit Writer Email address:	Sanford.phillips@la.gov		

Instructions

Permit Reference – Indicate specific portion(s) of the permit to which the remark relates (i.e. "Specific Condition 120", or "Section II Air Permits Briefing Sheet", etc.).

Remarks – Explain the basis for each remark. Provide regulatory citations where possible. If the remark is made due to an error or omission in the permit application this must be noted and the revised information ***must be submitted.*** Revised information may be submitted separately from this worksheet. Please be aware that revised information must be submitted in writing and certified by the Responsible Official, and if necessary, by a Professional Engineer licensed in Louisiana. *Please Note:* New or additional equipment, processes or operating conditions not addressed in the original permit application will be addressed on a case-by-case basis. The Department reserves the right to address such changes in a separate permit action.

DEQ Response – ***DO NOT COMPLETE THIS SECTION.*** This section will be completed by Air Permits Division of DEQ, included in the proposed permit package and made available for public review during any required public comment period.

- Additional rows may be added as necessary.
- Completed Form shall be emailed to the Permit writer in MS Word compatible format within the deadline specified in the email notification.
- ***DO NOT USE THIS FORM TO SUBMIT COMMENTS DURING THE OFFICIAL PUBLIC COMMENT PERIOD.***

Permit Reference	Remarks	Air Permits Division Response (for official use only)
Certified Letter	Please change C. Blake Hebert to Bobby Pitre	The change will be made.
Statement of Basis - General	Please change Company Name from LSU Service Station to Louisiana State University (This occurs throughout document)	The changes will be made.
Statement of Basis II	Veterinary Medicine Incinerator, Veterinary Medicine Generator and PMAC Generator are left off the Source list for Permit 0840-00128-V2	The changes will be made.
Statement of Basis III	Permitted Air Emissions SO2 before should be 4.27 tons per year	The changes will be made.
Statement of Basis IV	EQT 0030 was removed from the inventory	The changes will be made.
Statement of Basis IV	EQT 0066 should have exemptions for monitoring O2 and CO since this is a pathological waste incinerator	EQT 0066 will not be included on the exemption list. O2 and CO monitors are required for Biomedical Waste

	not a biological waste incinerator.	Incinerators and Refuse Incinerators only. The Veterinary Medicine Incinerator is classified as a Crematory. There are no requirements for crematories to have continuous monitoring of O2 and CO.
Statement of Basis IV	EQT 0067 and EQT00 68 should have exemptions similar to EQT0032 for SO2 & NOx	The change will be made.
Statement of Basis V	I calculate the Permitted Air emissions –after as PM10 30.03, SO2 5.172, NOx 220.86, CO 274.74 and VOC 11.24. This also adjusts the change	The change will be made.
Statement of Basis VI	The cap for Veterinary Medicine Boilers (GRP 002) is listed twice and the cap for the Turbines and Boilers (GRP 0003) is not shown	The change will be made.
Air Permit Briefing Sheet III	Permitted Air Emissions SO2 before should be 4.27 tons per year	The change will be made.
Air Permit Briefing Sheet III	I calculate the Permitted Air emissions –after as PM10 30.03, SO2 5.172, NOx 220.86, CO 274.74 and VOC 11.24. This also adjusts the change	The change will be made.
Air Permit Briefing Sheet XI	Exemptions should be as indicated above on Statement of Basis IV for EQT 0030, EQT 0066, EQT0067 and EQT 0068	The change will be made.
General Information – Related People	Please change C. Blake Hebert to Bobby Pitre as the responsible official. Please use Office of Facility Services, Louisiana State University, Baton Rouge, La 70803 as the mailing address	The change will be made.
General Information – Related People	Mailing address for Peter Davidson should be Office of Facility Services, Louisiana State University, Baton Rouge, La 70803	The change will be made.
Emission Rates for Criteria Pollutants	EQT 0041 is part of GRP 0003 and should not have avg lb/hr or tons/year listed .	The change will be made.
Emission Rates for Criteria Pollutants	Missing information on EQT 0068	The change will be made.
Inventories	Change EQT0041 (EPN1004) operating time to 8760 hr per year(All Year). This unit is under a cap for GRP003	The change will be made.