

## DRAFT - DISCHARGE UPDATE REPORT

**Project:** Temple-Inland Bogalusa Mill  
**Project Location:** Bogalusa, Louisiana  
**Report Prepared By:** Ed Cote  
**Date:** August 26, 2011  
**Status of Report:** Complete as of 10:00 AM August 27, pending additional analysis

**Weather Conditions:** AM: fair/sunny PM: fair/sunny  
**Temperature:** Max. 96°F  
**Cloud Cover:** (Yes) (No)  
**Precipitation:** (Yes) (No)

**Discharge:**  
**Beginning Time:** 6:56 am  
**Ending Time:** 6:45 pm  
**Discharge Stoppage:** (Yes) (No)

**Reason for Stoppage:**

NA

**Description:**

NA

**Activities, Remarks:**

- Discharge began at 6:56 am from the west weir
- Outfall monitoring was conducted in accordance with approved plan
- Flow maintained at an average of 2.1 million gallons per day (MGD)
- pH of discharge was within acceptable range
- Dye tracer (approximately 12.5 gallons) added by Louisiana Department of Environmental Quality (LDEQ) at 7:05 am
- ARCADIS assisted Temple-Inland with weir adjustments to maintain target flow
- Raised weir and stopped flow at 6:45

**Problems/Deficiencies/Corrective Actions:**

- None

**Samples Taken / Results:**

- Samples collected per frequencies indicated in Table 1 of approved Discharge Plan and results (to time indicated in above status) presented in attached table.

**Calibration Records on Field Testing Equipment**

- New ISCO 4230 flow meter at west weir was field-verified by vendor representatives
- Sampler set up for flow proportioning with new flow meter
- Outfall online pH and conductivity meters calibrated by Temple-Inland
- EBS sampling meters calibrated prior to start of discharge

**Oversight/Visitors**

- LDEQ representative on site to inspect and sample discharge
- ISCO flow meter vendor representatives
- EBS Sampling Laboratory
- Nalco antifoam representative
- State and public officials