

6.AC. Sector AC. Electronic, Electrical Equipment and Components, Photographic and Optical Goods

6.AC.1 Covered Storm Water Discharges

The requirements in 6.AC apply to storm water discharges associated with industrial activity from facilities that manufacture Electronic, Electrical Equipment and Components, Photographic and Optical Goods as identified by the SIC Codes specified in Table 1 of Part 1 of this MSGP for Sector AC facilities. You must comply with the Part 6 sector-specific requirements associated with your primary industrial activity and any co-located industrial activities as defined in Part 12. The sector-specific requirements apply to those areas of your facility where those sector-specific activities occur.

6.AC.2 Industrial Activities Covered by Sector AC

The SIC codes covered under Sector AC are:

3612-3699, 3812-3873, 3571-3579

The types of manufacturing activities that permittees under Sector AC are primarily engaged in are:

6.AC.2.1 measuring, analyzing, and controlling instruments;

6.AC.2.2 photographic, medical and optical goods;

6.AC.2.3 watches and clocks;

6.AC.2.4 computer and office equipment; and

6.AC.2.5 electrical and electronic equipment and components.

6.AC.3 Additional Monitoring

Table AC.1 – SECTOR-SPECIFIC NUMERIC EFFLUENT LIMITATIONS and BENCHMARK MONITORING			
Part of Permit Affected/Supplemental Requirements			
<i>Note: In addition to the following requirements, you must also comply with the requirements listed in Part 5 of the MSGP.</i>			
Subsector (You may be subject to requirements for more than one sector/subsector.)	Parameter	Benchmark Monitoring Concentration¹	Numeric Limitation²
Electronic, Electrical Equipment and Components (3612-3699), Measuring, Analyzing and Controlling Instrument; Photographic and Optical Goods (3812); Computer and Office Equipment (3571-3579)	Total Organic Carbon (TOC)	---	50 mg/L
	Oil & Grease	---	15 mg/L

¹ Monitor once/quarter for the year 2 and year 4 monitoring years (see 5.4.2 for possible year 4 monitoring waiver).

² The discharge from this permitted outfall shall not exceed a Daily Maximum of 50 mg/L Total Organic Carbon (TOC) or 15 mg/L Oil and Grease. **Unless required by Part 5.10 of this permit, analytical sampling and analysis of these parameters on a regular basis are not required.**