



DEPARTMENT OF ENVIRONMENTAL QUALITY

KATHLEEN BABINEAUX BLANCO JAN 08 2008

GOVERNOR

MIKE D. McDANIEL, Ph.D.

SECRETARY

CERTIFIED MAIL# 7004 1160 0003 2558 9917
RETURN RECEIPT REQUESTED

FILE NUMBER: LA0120243

AI NUMBER: 122552

ACTIVITY NUMBER: PER20040001

Guste Island Utility Company
Guste Island Wetland Assimilation Project
845 Galvez Street
Mandeville, LA 70448

Attention: Kelly J. McHugh, President

Subject: Louisiana Pollutant Discharge Elimination System (LPDES) permit to discharge treated sanitary wastewater into the Guste Island Restoration Wetlands, thence into High Bridge Canal, thence into the Tchefuncte River, thence into Lake Pontchartrain from a privately owned treatment works serving the Guste Island Estates, Timberlane Subdivision, Belle Pointe Subdivision, a proposed residential development, and flow from a residential area previously served by S.E.L.A.

Dear Mr. McHugh:

This Office has received comments from the general public in response to the public notice published in **The St. Tammany News** of Covington, LA on August 1, 2007 and September 12, 2007 and the Department of Environmental Quality Public Notice Mailing List and Electronic Mailing List on July 27, 2007 and September 10, 2007. DEQ's response to the comments are attached.

Pursuant to the Clean Water Act (33 U.S.C. 1251 *et seq.*), and the Louisiana Environmental Quality Act (La. R.S. 30:2001, *et seq.*), the attached LPDES permit has been issued. Provisions of this permit may be appealed in writing pursuant to La. R.S. 2024 (A) within 30 days of receipt of this permit. A request for a hearing must be sent to the following:

Louisiana Department of Environmental Quality
Office of the Secretary
Attention: Hearings Clerk, Legal Affairs Division
Post Office Box 4302
Baton Rouge, Louisiana 70821-4302

To ensure that all correspondence regarding this facility is properly filed into the Department's Electronic Data Management System, you must reference your Agency Interest number AI 122552 and LPDES permit number LA0120243 on all future correspondence to this Department, including Discharge Monitoring Reports.

In accordance with Part II, Paragraph 10 of the permit, monitoring results should be reported on a Discharge Monitoring Report (DMR) form as per the schedule specified. A copy of the form to be used is attached for your convenience.

ENVIRONMENTAL SERVICES

: PO BOX 4313, BATON ROUGE, LA 70821-4313

P:225-219-3181 F:225-219-3309

WWW.DEQ.LOUISIANA.GOV

Guste Island Utility Company
Guste Island Wetland Assimilation Project
RE: LA0120243; AI122552; PER20040001
Page Two

Should you have any questions concerning any part of the permit, please contact Mr. Eura DeHart, Office of Environmental Services, Water Permits Division, Municipal and General Water Permits Section, at the address on the preceding page or telephone (225) 219-3092.

Sincerely,



Chuck Carr Brown, Ph. D.
Assistant Secretary

ed

Attachments (Final Permit - Parts I-III, DMR, Responses to Comments, Statement of Basis Addendum, and Wetland Monitoring Forms)

cc: IO-W

Mr. Eura DeHart
Water Permits Division

ec: Mr. Ronnie Bean
Water Permits Division

Ms. Evelyn Rosborough, 6WQ-CA
U.S. Environmental Protection Agency, Region VI

Public Health Chief Engineer
Office of Public Health
Department of Health and Hospitals

Permit Compliance Unit
Office of Environmental Compliance

Blaise Guzzardo
Southeast Regional Office
Office of Environmental Compliance

Kris Pintado
Dugan Sabins
Office of Environmental Assessment



PERMIT NUMBER: LA0120243
AGENCY INTEREST NO.: 122552
ACTIVITY NO.: PER20040001

OFFICE OF ENVIRONMENTAL SERVICES

Water Discharge Permit

Pursuant to the Clean Water Act, as amended (33 U.S.C. 1251 et seq.), and the Louisiana Environmental Quality Act, as amended (La. R. S. 30:2001 et seq.), rules and regulations effective or promulgated under the authority of said Acts, and in reliance on statements and representations heretofore made in the application, a Louisiana Pollutant Discharge Elimination System permit is issued authorizing

Guste Island Utility Company
Guste Island Wetland Assimilation Project
845 Galvez Street
Mandeville, LA 70448

Type Facility: privately owned treatment works serving the Guste Island Estates, Timberlane Subdivision, Belle Point Subdivision, a proposed residential development, and flow from a residential area previously served by S.E.L.A.

Location: Guste Island Road off of Highway 22 in Madisonville, St. Tammany Parish

Receiving Waters: Guste Island Restoration Wetlands, thence into High Bridge Canal, thence into the Tchefuncte River, thence into Lake Pontchartrain (040803)

to discharge in accordance with effluent limitations, monitoring requirements, and other conditions set forth in Parts I, II, and III attached hereto.

This permit shall become effective on

1/7/08

This permit and the authorization to discharge shall expire five (5) years from the effective date of the permit.

Issued on

1/7/08

Chuck Carr Brown, Ph. D.
Assistant Secretary

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning the effective date of the permit and lasting through the expiration date of the permit the permittee is authorized to discharge from:

Outfall 001, treated sanitary wastewater (estimated flow is 0.6 MGD).

Such discharges shall be limited and monitored by the permittee as specified below:

<u>Effluent Characteristic</u>	Storet <u>Code</u>	<u>Discharge Limitations</u>				<u>Monitoring Requirements</u>	
		<u>Weekly Avg.</u>	<u>Monthly Avg.</u>	other units (specify)		<u>Measurement Frequency</u>	<u>Sample Type</u>
Flow-MGD	50050	Report	Report	---	---	Continuous	Recorder ³
BOD ₅	00310	---	150	30 mg/l	45 mg/l	1/week	3 Hr. Composite
TSS	00530	---	450	90 mg/l	135 mg/l	1/week	3 Hr. Composite
Total Nitrogen ^{2, 6}	00600	---	Report	Report mg/l	Report mg/l	Quarterly	3 Hr. Composite
Total Phosphorus ⁵	00665	---	Report	Report mg/l	Report mg/l	Quarterly	3 Hr. Composite
Ammonia	00610	---	Report	Report mg/l	Report mg/l	Quarterly	3 Hr. Composite
Fecal Coliforms ¹ colonies/100ml	74055	---	---	200	400	2/month	Grab
pH (Standard Units) ⁴	00400	---	---	---	---	2/month	Grab
Wetland Monitoring ⁵							

¹ See Part II, Section A, Paragraph # 9

² Total Nitrogen will be reported as the sum of Total Kjeldal Nitrogen (TKN) plus Nitrate and Nitrite.

³ Includes totalizing meter or totalizer.

⁴ The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units. The permittee shall report on the Discharge Monitoring Reports both the minimum and maximum instantaneous pH values measured.

⁵ See Part II, Section B, Wetland System Monitoring Requirements.

There is one outfall, in which the water is distributed via a header system over the upper end of the wetland site and flows southerly toward the receiving canal. The header system will ensure that the treated effluent is spread evenly over the wetland surface.

⁶ Data obtained from the TN and TP analysis will be used to derive nutrient loading per square meter of wetlands which will be reported in the Annual Wetland Monitoring Report. Nutrient Loading shall not exceed 15 grams Total Nitrogen per square meter per year and 4 grams Total Phosphorous per square meter per year.

PART II

OTHER REQUIREMENTS

In addition to the standard conditions required in all permits and listed in Part III, the office has established the following additional requirements in accordance with the Louisiana Water Quality Regulations.

SECTION A. GENERAL STATEMENTS

1. The Department of Environmental Quality reserves the right to impose more stringent discharge limitations and/or additional restrictions in the future to maintain the water quality integrity and the designated uses of the receiving water bodies based upon water quality studies. These studies may indicate the need for more advanced wastewater treatment. Studies of similar dischargers and receiving water bodies have resulted in monthly average effluent limitations of 5 mg/l CBOD₅, and 2 mg/l NH₃-N. Therefore, prior to upgrading or expanding this facility, the permittee should contact the Department to determine the status of the work being done to establish future effluent limitations and additional permit conditions.
2. This permit does not in any way authorize the permittee to discharge a pollutant not listed or quantified in the application or limited or monitored for in the permit.
3. Authorization to discharge pursuant to the conditions of this permit does not relieve the permittee of any liability for damages to state waters or private property. For discharges to private land, this permit does not relieve the permittee from obtaining proper approval from the landowner for appropriate easements and rights of way.
4. For definitions of monitoring and sampling terminology see Part III, Section F.
5. 24-hour Oral Reporting: Daily Maximum Limitation Violations

Under the provisions of Part III Section D.6.e.(3) of this permit, violations of daily maximum limitations for the following pollutants shall be reported orally to the Office of Environmental Compliance within 24 hours from the time the permittee became aware of the violation followed by a written report in five days.

Pollutants: None

6. As an exception to Part III Section D.6.e.(1), the permittee shall report all overflows in the collection system with the Discharge Monitoring Report submittal. These reports shall be summarized and reported in tabular format. The summaries shall include: the date, time, duration, location, estimated volume, and cause of the overflow; observed environmental impacts from the overflow; actions taken to address the overflow; and the ultimate discharge location if not contained (e.g., storm sewer system, ditch, tributary). All other overflows and overflows which endanger human health or the environment must be reported in the manner described in Part III, Section D.6 of the permit.
7. In accordance with La.R.S.40:1149, it shall be unlawful for any person, firm, or corporation, both municipal and private, operating a water supply system or sewerage system to operate same unless the competency of the operator is duly certified to by the State Health Officer. Furthermore, it shall be unlawful for any person to perform the duties of an operator without being duly certified. Therefore, the Guste Island Utility Company should take whatever action is necessary to comply with La.R.S. 40:1149.

OTHER REQUIREMENTS (cont.)

8. The permittee shall achieve compliance with the effluent limitations and monitoring requirements specified for discharges in accordance with the following schedule:

EFFECTIVE DATE OF THE PERMIT

9. Future water quality studies may indicate potential toxicity from the presence of residual chlorine in the treatment facility's effluent. Therefore, the permittee is hereby advised that a future Total Residual Chlorine Limit may be required if chlorine is used as a method of disinfection. In many cases, this becomes a NO MEASURABLE Total Residual Chlorine Limit. If such a limit were imposed, the permittee would be required to provide for dechlorination of the effluent prior to a discharge.

10. DISCHARGE MONITORING REPORTS

Monitoring results must be reported on a Discharge Monitoring Report (DMR) form (EPA No. 3320-1 or an approved substitute). All monitoring reports must be retained for a period of at least three (3) years from the date of the sample measurement. The permittee shall make available to this Department, upon request, copies of all monitoring data required by this permit.

If there is a no discharge event at any of the monitored outfall(s) during the reporting period, enter "No Discharge" in the upper right corner of the Discharge Monitoring Report.

Discharge Monitoring Report (DMR) forms shall be prepared and submitted for each outfall per the instructions and submission schedules below:

- A. For monitoring frequencies once per month or more often (i.e. 1/week, 1/day, 1/batch, 1/discharge event), one DMR form per month (summarize monitoring results monthly) must be prepared and submitted quarterly.
- B. For once per quarter monitoring frequencies, one DMR form per quarter must be prepared and submitted quarterly.
- C. For once per 6 months monitoring frequencies, one DMR form per six month period must be prepared and submitted semi-annually.
- D. For once per year monitoring frequencies, one DMR form per year must be submitted annually.

Quarterly Submission Schedule

<u>Monitoring Period</u>	<u>DMR Postmark Date</u>
January, February, March	April 28th
April, May, June	July 28th
July, August, September	October 28th
October, November, December	January 28th

OTHER REQUIREMENTS (cont.)

Semiannual Submission Schedule

<u>Monitoring Period</u>	<u>DMR Postmark Date</u>
January - June	July 28th
July - December	January 28 th

Annual Submission Schedule

<u>Monitoring Period</u>	<u>DMR Postmark Date</u>
January-December	January 28th

Duplicate copies of DMRs (one set of originals and one set of copies) signed and certified as required by LAC 33:IX.2503, and all other reports (one set of originals) required by this permit shall be submitted to the Permit Compliance Unit (one set of copies) at the following address:

Department of Environmental Quality
Office of Environmental Compliance
Enforcement Division
Post Office Box 4312
Baton Rouge, Louisiana 70821-4312
Attention: Permit Compliance Unit

OTHER REQUIREMENTS (cont.)

SECTION B. WETLAND SYSTEM MONITORING REQUIREMENTS

1. **MONITORING AND REPORTING** shall apply to both wastewater management area and control area as defined in the following chart:

PARAMETER	WETLAND COMPONENT		
	FLORA	SEDIMENT	SURFACE WATER
Species Classification and Survival	A		
Growth Studies	A ₁		
Water Stage			M
Metals Analysis: Mg, Pb, Cd, Cr, Cu, Zn, Fe, Ni, Ag, Se	P ₁	P ₁	S
Nutrient Analysis I: TKN, TP	P ₁	P ₁	S
Nutrient Analysis II: NH ₃ N, NO ₂ N, NO ₃ N, PO ₄		P ₁	S
Others: BOD ₅ , TSS, pH, Dissolved Oxygen			S

If loading rates exceed 15 g/m²/yr total nitrogen or 4 g/m²/yr total phosphorus, then either the loading rates must be reduced or the assimilation area must be increased.

Water quality will be monitored by taking water samples along the path of flow of the effluent in the treatment site and from one or more control sites.

- **Sampling and classifying the flora** present and determining percentage of each vegetative species. The sampling will provide information on whether dominance and species diversity of the community is being maintained.
- **Growth studies** of vegetative productivity, which will provide an indication of health and vigor of the plant community. (Total height of planted species in supplemental plantings, in lieu of vegetative production).
- **Water stage** is a gauged measurement of the water depth, which will assist in determining stress in the wetlands from hydrologic loadings and will determine the existence of a zone of influence resulting from wastewater applications. The zone around the discharge serves to assimilate the wastewater most effectively. This zone grows larger as wastewater continues to be discharged and the assimilative capacity of the immediate area becomes saturated.
- **Metals and nutrient data from plant tissue samples**, which will identify excesses or deficiencies that could become problematic.
- **Sediment analysis for metals, and nutrients**, which will indicate whether or not metals are bound and buried in the sediments, and nutrients assimilated.
- **Corresponding analysis of surface water** must be made to provide a comparison of water quality in the vicinity of the discharge and at increasing distance from it.

OTHER REQUIREMENTS (cont.)

Compared to data from the baseline study and control area, the effects of the discharge on the biological integrity (as defined above) may be accurately assessed.

Sampling in the **WASTEWATER MANAGEMENT AREA** must be conducted as follows:

- Collection of a minimum of three samples per site in each of three sites: 1) 100 meters from the discharge point, 2) midway, and 3) at the point where water leaves the assimilation area.

Sampling for the **CONTROL AREA** must be conducted as follows:

Collection of a minimum of three samples per site in each of the two sites. All three samples will be taken from a site or sites similar to the wastewater management area.

The control area will be outside of the levee system, near the following coordinates:

Latitude: + 30° 23' 17" North

Longitude: - 90° 14' 29" West

A: ANNUALLY. Sample once per year at all three (3) **WASTEWATER ASSIMILATION AREA** sites and the two (2) **CONTROL AREA** sites and included in the yearly report.

A₁ – Stem growth and litter fall; height of the planted trees shall be measured annually in the assimilation area only. The change from the previous year shall be noted in the annual report.

M: MONTHLY. Samples should be taken at all three (3) **WASTEWATER MANAGEMENT AREAS** and the two (2) **CONTROL AREAS** each month and include in the yearly report.

P: PERIODICALLY. Sampling must be made once during March through May, and once during September through November in the fourth year of the permit period for all three (3) **WASTEWATER MANAGEMENT AREAS** and the two (2) **CONTROL AREAS**.

P₁ – Sample preservation, handling, and analysis must meet the specifications of the Test Methods for Evaluating Solid Waste Physical/Chemical Methods, third edition (EPA Publication Number SW-846, 1986, or most recent revision) or an equivalent substitute as approved by the administrative authority.

S: SEMI-ANNUAL. Sample twice per year: once during September through February, and once during March through August (sampling events must be a minimum of 4 months apart) for all three (3) **WASTEWATER MANAGEMENT AREAS** and the two (2) **CONTROL AREAS** and included in the yearly report.

Parameters are to be sampled and monitored for the specified wetland component at all wastewater management areas and the control areas.

OTHER REQUIREMENTS (cont.)

WETLAND MONITORING REPORT REQUIREMENT SCHEDULE	
REPORT	DUE DATE
Annual Wetland Monitoring Report ¹	NO LATER THAN 30 days past one (1) year from the effective date of the permit
Annual Wetland Monitoring Report ¹	NO LATER THAN 30 days past two (2) years from the effective date of the permit
Annual Wetland Monitoring Report ¹	NO LATER THAN 30 days past three (3) years from the effective date of the permit
Annual Wetland Monitoring Report ¹ and the Fourth Year Wetland Monitoring Report ²	NO LATER THAN 30 days past four (4) years from the effective date of the permit
Annual Wetland Monitoring Report ¹	NO LATER THAN 30 days past five (5) years from the effective date of the permit

¹ Annual Wetland Monitoring Report **must be submitted on the attached forms** and shall consist of:

Parameter	Wetland Component
Growth Studies	Flora
Water Stages	Surface Water
Metal Analysis	Surface Water
Nutrient Analysis I	Surface Water
Nutrient Analysis II	Surface Water
Other Parameters	Surface Water
Total Nitrogen and Total Phosphorus Loadings	Assimilation Area

² Fourth Year Wetland Monitoring Report **must be submitted on the attached forms** and shall consist of:

Parameter	Wetland Component
Species Classification	Flora
Metal Analysis	Flora & Sediment
Nutrient Analysis I	Flora & Sediment
Nutrient Analysis II	Sediment

In the event that a permit is not reissued in a timely manner, the Annual Wetland Monitoring Report shall be submitted for the years following the expiration date of the permit and shall be due 30 days after the anniversary of the effective date of this permit.

OTHER REQUIREMENTS (cont.)

A copy of each report required by this permit shall be submitted to the Permits Compliance Unit, and shall also be submitted to the Permits Division and Planning Division at the following addresses:

Louisiana Department of Environmental Quality
Office of Environmental Compliance
Enforcement Division
Post Office Box 4312
Baton Rouge, Louisiana 70821-4312
Attention: Permit Compliance Unit

Louisiana Department of Environmental Quality
Office of Environmental Services
Water Permits Division
Municipal and General Water Permits Section
Post Office Box 4313
Baton Rouge, Louisiana 70821-4313

Louisiana Department of Environmental Quality
Office of Environmental Assessment
Environmental Planning Division
Post Office Box 4314
Baton Rouge, Louisiana 70821-4314

2. If wetland monitoring shows that there is:

- **SIGNIFICANT DECREASE IN FAUNAL SPECIES DIVERSITY**
- **SIGNIFICANT CHANGE IN THE INITIAL SPECIES PLANTING PERCENTAGE (%)**
- **SIGNIFICANT INCREASE IN INVASIVE SPECIES**

then, within 180 days of a significant change in any of the above required biological criteria, the permittee shall develop a study and test procedures to determine the origination of the cause. A determination shall be made to indicate whether or not the impact to the wetland was caused by the effluent. The permittee must demonstrate to the Department what has caused the problem and develop a comprehensive plan for the expeditious elimination and prevention of such cause. The plan shall provide specific corrective actions to be taken to achieve compliance with the above biological criteria within the shortest period of time. In addition, the permittee shall submit the following with the Discharge Monitoring Report in the months of January, April, July and October:

- i. any data and/or substantiating documentation which identifies the pollutant(s) and/or source(s) of effluent toxicity;
- ii. any studies/evaluations and results on the treatability of the facility's effluent toxicity;
- iii. any data which identifies effluent toxicity control mechanisms or measures that could be installed or implemented which would reduce or remove the effluent toxicity; and steps taken or proposed to be taken to prevent such violation(s) from recurring.

In addition, if studies and tests indicate that the impact to the restoration wetland was caused by the effluent, then this permit may be reopened to include appropriate limitations and conditions to ensure protection of water quality standards.

OTHER REQUIREMENTS (cont.)

3. **If loading rates exceed 15 g/m²/yr total nitrogen or 4 g/m²/yr total phosphorus, then either the loading rates must be reduced or the assimilation area must be increased.**
4. The following actions shall be performed by the permittee for establishment of a hardwood/swamp forest:
 - a. Seedlings of bald cypress, tupelo gum (*Nyssa aquatica*), green ash (*Fraxinus pennsylvanica*), and red maple (*Acer rubrum v. drummondii*) shall be planted in assimilation area between January 15 and May 31, 2008. The plantings shall occupy a spacing of 12 feet by 12 feet.
 - b. A survival rate of 50% shall be required. Replantings shall be conducted as necessary but not less than annually between January 15 and February 28 of each year for the first five years of the permit if the 50% survival rate is not met.
 - c. Monitoring of the survival rate will be accomplished by establishing three (3) 10 x 100 m quadrates and monitoring the plantings in the quadrates in the assimilation area. These quadrates shall be different from those established for wetland monitoring requirements established above.
 - d. Firebreaks will be established around the perimeter of the planting area or at intervals deemed necessary by Guste Island Utilities.
 - e. A discussion of the plantings, survival rate, and additional plantings must be reported each year in the Annual Wetland Monitoring Report.
5. **The following monitoring shall be conducted at the pumping station at High Bridge Canal until removal of the levee: total nitrogen, total phosphorus, and ammonia. The monitoring shall be conducted quarterly and reported in the Annual Wetland Monitoring Report.**

Suggestions for sampling during the wetland monitoring phase. These suggestions are from *The Use of Louisiana Swamp Forests for Application of Treated Municipal Wastewater: Standard Operating Procedures for Monitoring the Effects of Effluent Discharge*. John W. Day, Jr., Joel Lindsey, Jason N. Day, and Robert R. Lane, Comite Resources, Inc. (Used with the permission of Dr. John W. Day, Jr., March 14, 2003)

WATER QUALITY

1. **Dissolved oxygen and water temperature:** is measured using a Yellow Springs Instrument Co. meter or an ORION Model 820 Dissolved Oxygen meter or equivalent. The probe will be calibrated within four hours of use with a known standard (100% air saturation).
2. **pH & TDS:** Measurements of pH and TDS (Total Dissolved Solids) are made in the field using a Corning Checkmate M90 Field System or equivalent. Water samples will be collected in 500 ml polyethylene bottles and returned to the laboratory where pH will again be measured in the lab using a Jenco Markson pH meter, Model 6100 or equivalent.
3. **Nutrients:** Discrete water samples will be taken 5 to 10 cm below the water surface with effort taken not to stir bottom sediments or include any film that may be present on water surface. Samples are collected in 500 ml acid washed polyethylene bottles. The samples will be immediately stored at 4°C, on ice, for preservation. The samples will be transported to an analytical laboratory, and within 24 hours filtered and sub-sampled. Samples analyzed for NO₂ + NO₃, NH₄ and PO₄ will be filtered in the laboratory using 0.45 um Whatman GF/F glass fiber filters or equivalent, and unfiltered samples will be sub-sampled into 125 mL bottles. Both filtered and unfiltered samples will be frozen until analysis. The samples will be analyzed for nitrite + nitrate (NO₂+NO₃-N), ammonium (NH₄-N), total nitrogen (TN), total phosphorus (TP), and phosphate (PO₄-P) by an EPA and DEQ approved analytical laboratory using Standard Methods.
4. **Total Suspended Solids:** TSS will be determined by filtering 100-200 mL of sample water through re-rinsed, dried and weighed 47 mm 0.45 um Whatman GF/F glass fiber filters. Filters will then be dried for 1 hr at 105° C, weighed.

OTHER REQUIREMENTS (cont.)

dried for another 15 minutes, and reweighed for quality assurance (Standard Methods 1992).

5. **Biological Oxygen Demand:** BOD samples will be collected in standard 300 ml glass BOD bottles. BOD₅ analysis will be from water samples collected in 500ml polyethylene bottles, stored on ice and taken to the laboratory for analysis. Initial D.O. will be measured within 24 hours. Final D.O. will be measured after 5 days of incubation at 20°C. Measurement of BOD is the responsibility of the facility.
6. **ICP Analysis:** Water samples will be collected from the effluent pipe and surface water in the treatment and control area for ICP and IC analysis. The following will be measured: Mg, Pb, Zn, and Cr. The results of the ICP and IC analysis will be used in reporting the metals and nutrient parameters.
7. **Coliform Analysis:** Fecal coliform (i.e. *Escherichia coli*) will be tested using membrane filtration as a field preparation, and then sent to an EPA certified laboratory for analysis. Ten ml of sample water will be passed through a 0.45 micron filter. The filter will be stored in a sterile petri dish and brought within 8 hrs to a certified laboratory for analysis.
8. **Statistical Analysis:** One-way analysis of variance analysis will be carried out to compare treatment and control area parameters using statistical software. An alpha probability level of <0.05 will be used to define a significant difference. Comparisons of means with significant ANOVA tests will be made using Tukey-Kramer Honestly Significant Difference (HSD) test (Sall and Lehman 1996). Other statistical tests may be used as appropriate.

SOILS

1. **Sediment Cores:** At least one sediment core will be taken from each study site (Treatment & Control) with a 7.5 cm stainless steel corer. Following the removal of large litter debris, the top 10 to 20 cm of the samples will be separated by horizon, dried, ground and analyzed. Parameters measured will include: pH, electrical conductivity (EC), Mg, Pb, Cd, Cr, Cu, Zn, Fe, Ni, Ag, Se, NH₃-N, NO₂+NO₃-N, PO₄-P, TKN, and TP. All elemental analyses will be done using an inductively coupled argon plasma quantometer (ICP). Results will be reported as the average of duplicate analyses that are within a 10% confidence interval. The results will be based on oven dry weight.

VEGETATION

To sample forest vegetation, three or more subplots should be established at each main plot. Normally, main plots will be established at a near, mid, and outlet locations in the Treatment site, and another main plot established at a Control site. The plots will be orientated perpendicular to the hydrological gradient.

1. **Tree Species Composition:** The relative importance of each major tree species in both the treatment and control areas will be based on the density (total number) and frequency of occurrence in each of the plots using equations 1 and 2 (Barbour et al. 1987).

$$\text{Relative density} = (\text{individuals of a species})/(\text{total individuals of all species}) \quad (1)$$

$$\text{Relative frequency} = (\text{frequency of species})/(\text{total frequency of all species in area}) \quad (2)$$

2. **Nutrient and Metals Analysis of Green Leaves:** Green leaf samples should be collected during the last year of the monitoring from the major species in the treatment and control areas, once during March through May and once during September through November. Samples will be oven-dried at 70°C for at least 48 hours, ground in a Wiley

OTHER REQUIREMENTS (cont.)

mill to pass a 40 mesh screen, and stored in whirl-pak bags. Samples will be analyzed in the laboratory for Mg, Pb, Cd, Cr, Cu, Zn, Fe, Ni, Ag, Se, TKN and TP. The tissue analyses should be done by a wet digestion method.

3. **Marsh Vegetation Production:** Net production in areas dominated by non-woody herbaceous vegetation will be determined by end of season live (EOSL) biomass analysis. Sampling should be conducted during the last week of September or the first week of October. At least five 0.06 m² clip plots will be taken at each location using randomly placed quadrants. Vegetation within the quadrant will be cut as close to the surface as possible, stored in labeled paper bags, brought back to the laboratory, and refrigerated until processing. Live material will be separated from dead, and dried at 60° C to a constant weight. All data will be presented on a live dry weight per square meter basis (g dry wt m⁻²).

PART III
STANDARD CONDITIONS FOR LPDES PERMITS

SECTION A. GENERAL CONDITIONS

1. Introduction

In accordance with the provisions of LAC 33:IX.2701, et seq., this permit incorporates either expressly or by reference ALL conditions and requirements applicable to Louisiana Pollutant Discharge Elimination System Permits (LPDES) set forth in the Louisiana Environmental Quality Act (LEQA), as amended, as well as ALL applicable regulations.

2. Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act (CWA) and the Louisiana Environmental Quality Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

3. Penalties for Violation of Permit Conditions

a. LA. R. S. 30:2025 provides for civil penalties for violations of these regulations and the Louisiana Environmental Quality Act. LA. R. S. 30:2076.2 provides for criminal penalties for violation of any provisions of the LPDES or any order or any permit condition or limitation issued under or implementing any provisions of the LPDES program. (See Section E. Penalties for Violation of Permit Conditions for additional details).

b. Any person may be assessed an administrative penalty by the State Administrative Authority under LA. R. S. 30:2025 for violating a permit condition or limitation implementing any of the requirements of the LPDES program in a permit issued under the regulations or the Louisiana Environmental Quality Act.

4. Toxic Pollutants

a. Other effluent limitations and standards under Sections 301, 302, 303, 307, 318, and 405 of the Clean Water Act. If any applicable toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under Section 307(a) of the Clean Water Act for a toxic pollutant and that standard or prohibition is more stringent than any limitation on the pollutant in this permit, the state administrative authority shall institute proceedings under these regulations to modify or revoke and reissue the permit to conform to the toxic effluent standard or prohibition.

b. The permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under Section 405(d) of the Clean Water Act within the time provided in the regulations that establish these standards or prohibitions, or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.

5. Duty to Reapply

a. Individual Permits. If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. The new application shall be submitted at least 180 days before the expiration date of the existing permit, unless permission for a later date has been granted by the state administrative authority. (The state administrative authority shall not grant permission for applications to be submitted later than the expiration date of the existing permit.) Continuation of expiring permits shall be governed by regulations promulgated at LAC 33:IX.2321 and any subsequent amendments.

- b. **General Permits.** General permits expire five years after the effective date. The 180-day reapplication period as defined above is not applicable to general permit authorizations. Reissued general permits may provide automatic coverage for permittees authorized under the previous version of the permit, and no new application is required. Requirements for obtaining authorization under the reissued general permit will be outlined in Part I of the new permit. Permittees authorized to discharge under an expiring general permit should follow the requirements for obtaining coverage under the new general permit to maintain discharge authorization.

6. Permit Action

This permit may be modified, revoked and reissued, or terminated for cause in accordance with LAC 33:IX.2903, 2905, 2907, 3105 and 6509. The causes may include, but are not limited to, the following:

- a. Noncompliance by the permittee with any condition of the permit;
- b. The permittee's failure in the application or during the permit issuance process to disclose fully all relevant facts, or the permittee's misrepresentation of any relevant facts at any time;
- c. A determination that the permitted activity endangers human health or the environment and can only be regulated to acceptable levels by permit modification or termination;
- d. A change in any condition that requires either a temporary or a permanent reduction or elimination of any discharge; or
- e. Failure to pay applicable fees under the provisions of LAC 33: IX. Chapter 13;
- f. Change of ownership or operational control;

The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

7. Property Rights

This permit does not convey any property rights of any sort, or any exclusive privilege.

8. Duty to Provide Information

The permittee shall furnish to the state administrative authority, within a reasonable time, any information which the state administrative authority may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the state administrative authority, upon request, copies of records required to be kept by this permit.

9. Criminal and Civil Liability

Except as provided in permit conditions on "Bypassing" and "Upsets", nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance. Any false or materially misleading representation or concealment of information required to be reported by the provisions of the permit, the Act, or applicable regulations, which avoids or effectively defeats the regulatory purpose of the Permit may subject the Permittee to criminal enforcement pursuant to La. R.S. 30:2025.

10. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject under Section 311 of the Clean Water Act.

11. State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable State law or regulation under authority preserved by Section 510 of the Clean Water Act.

12. Severability

If any provision of these rules and regulations, or the application thereof, is held to be invalid, the remaining provisions of these rules and regulations shall not be affected, so long as they can be given effect without the invalid provision. To this end, the provisions of these rules and regulations are declared to be severable.

13. Dilution

A permittee shall not achieve any effluent concentration by dilution unless specifically authorized in the permit. A permittee shall not increase the use of process water or cooling water or otherwise attempt to dilute a discharge as a partial or complete substitute for adequate treatment to achieve permit limitations or water quality.

14. Facilities Requiring Approval from Other State Agencies

In accordance with La R.S.40.4(A)(6) the plans and specifications of all sanitary sewerage treatment systems, both public and private, must be approved by the Department of Health and Hospitals state health officer or his designee. It is unlawful for any person, firm, or corporation, both municipal and private to operate a sanitary sewage treatment facility without proper authorization from the state health officer.

In accordance with La R.S.40.1149, it is unlawful for any person, firm or corporation, both municipal and private, operating a sewerage system to operate that system unless the competency of the operator is duly certified by the Department of Health and Hospitals state health officer. Furthermore, it is unlawful for any person to perform the duties of an operator without being duly certified.

In accordance with La R.S.48.385, it is unlawful for any industrial wastes, sewage, septic tanks effluent, or any noxious or harmful matter, solid, liquid or gaseous to be discharged into the side or cross ditches or placed upon the rights-of-ways of state highways without the prior written consent of the Department of Transportation and Development chief engineer or his duly authorized representative and of the secretary of the Department of Health and Hospitals.

SECTION B. PROPER OPERATION AND MAINTENANCE**1. Need to Halt or Reduce not a Defense**

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

2. Duty to Mitigate

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment. The permittee shall also take all reasonable steps to minimize or correct any adverse impact on the environment resulting from noncompliance with the permit, including such accelerated or additional monitoring as necessary to determine the nature and impact of the noncomplying discharge.

3. Proper Operation and Maintenance

- a. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.
- b. The permittee shall provide an adequate operating staff which is duly qualified to carry out operation, maintenance and other functions necessary to ensure compliance with the conditions of this permit.

4. Bypass of Treatment Facilities

- a. Bypass. The intentional diversion of waste streams from any portion of a treatment facility.
- b. Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Section B.4.c. and 4.d of these standard conditions.
- c. Notice
 - (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice to the Office of Environmental Services, Water Permits Division, if possible at least ten days before the date of the bypass.
 - (2) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in LAC 33:IX.2701.L.6, (24-hour notice) and Section D.6.e. of these standard conditions.
- d. Prohibition of bypass
 - (1) Bypass is prohibited, and the state administrative authority may take enforcement action against a permittee for bypass, unless:
 - (a) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - (b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and,
 - (c) The permittee submitted notices as required by Section B.4.c of these standard conditions.
 - (2) The state administrative authority may approve an anticipated bypass after considering its adverse effects, if the state administrative authority determines that it will meet the three conditions listed in Section B.4.d(1) of these standard conditions.

5. Upset Conditions

- a. Upset. An exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
- b. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of Section B.5.c. are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- c. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
 - (2) The permitted facility was at the time being properly operated; and
 - (3) The permittee submitted notice of the upset as required by LAC 33:IX.2701.L.6.b.ii. and Section D.6.e.(2) of these standard conditions; and

(4) The permittee complied with any remedial measures required by Section B.2 of these standard conditions.

d. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

6. Removed Substances

Solids, sewage sludges, filter backwash, or other pollutants removed in the course of treatment or wastewater control shall be properly disposed of in a manner such as to prevent any pollutant from such materials from entering waters of the state and in accordance with environmental regulations.

7. Percent Removal

For publicly owned treatment works, the 30-day average percent removal for Biochemical Oxygen Demand and Total Suspended Solids shall not be less than 85 percent in accordance with LAC 33:IX.5905.A.3. and B.3.

SECTION C. MONITORING AND RECORDS

1. Inspection and Entry

The permittee shall allow the state administrative authority or an authorized representative (including an authorized contractor acting as a representative of the Administrator), upon the presentation of credentials and other documents as may be required by the law to:

a. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit.

Enter upon the permittee's premises where a discharge source is or might be located or in which monitoring equipment or records required by a permit are kept for inspection or sampling purposes. Most inspections will be unannounced and should be allowed to begin immediately, but in no case shall begin more than thirty (30) minutes after the time the inspector presents his/her credentials and announces the purpose(s) of the inspection. Delay in excess of thirty (30) minutes shall constitute a violation of this permit. However, additional time can be granted if the inspector or the Administrative Authority determines that the circumstances warrant such action; and

b. Have access to and copy, at reasonable times, any records that the department or its authorized representative determines are necessary for the enforcement of this permit. For records maintained in either a central or private office that is open only during normal office hours and is closed at the time of inspection, the records shall be made available as soon as the office is open, but in no case later than the close of business the next working day;

c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and

d. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act or the Louisiana Environmental Quality Act, any substances or parameters at any location.

e. Sample Collection

(1) When the inspector announces that samples will be collected, the permittee will be given an additional thirty (30) minutes to prepare containers in order to collect duplicates. If the permittee cannot obtain and prepare sample containers within this time, he is considered to have waived his right to collect duplicate samples and the sampling will proceed immediately. Further delay on the part of the permittee in allowing initiation of the sampling will constitute a violation of this permit.

(2) At the discretion of the administrative authority, sample collection shall proceed immediately (without the additional 30 minutes described in Section C.1.a. above) and the inspector shall supply the permittee with a duplicate sample.

- f. It shall be the responsibility of the permittee to ensure that a facility representative familiar with provisions of its wastewater discharge permit, including any other conditions or limitations, be available either by phone or in person at the facility during all hours of operation. The absence of such personnel on-site who are familiar with the permit shall not be grounds for delaying the initiation of an inspection except in situations as described in Section C.1.b. of these standard conditions. The permittee shall be responsible for providing witnesses/escorts during inspections. Inspectors shall abide by all company safety rules and shall be equipped with standard safety equipment (hard hat, safety shoes, safety glasses) normally required by industrial facilities.
- g. Upon written request copies of field notes, drawings, etc., taken by department personnel during an inspection shall be provided to the permittee after the final inspection report has been completed.

2. Representative Sampling

Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. All samples shall be taken at the outfall location(s) indicated in the permit. The state administrative authority shall be notified prior to any changes in the outfall location(s). Any changes in the outfall location(s) may be subject to modification, revocation and reissuance in accordance with LAC 33:IX.2903.

3. Retention of Records

Except for records of monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR 503), the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the sample, measurement, report, or application. This period may be extended by request of the state administrative authority at any time.

4. Record Contents

Records of monitoring information shall include:

- a. The date, exact place, and time of sampling or measurements;
- b. The individual(s) who performed the sampling or measurements;
- c. The date(s) analyses were performed;
- d. The time(s) analyses were begun;
- e. The individual(s) who performed the analyses;
- f. The analytical techniques or methods used;
- g. The results of such analyses; and
- h. The results of all quality control procedures.

5. Monitoring Procedures

- a. Monitoring results must be conducted according to test procedures approved under 40 CFR Part 136 or, in the case of sludge use or disposal, approved under 40 CFR Part 136 unless otherwise specified in 40 CFR Part 503, unless other test procedures have been specified in this permit.
- b. The permittee shall calibrate and perform maintenance procedures on all monitoring and analytical instruments at intervals frequent enough to insure accuracy of measurements and shall maintain appropriate records of such activities.
- c. The permittee or designated laboratory shall have an adequate analytical quality assurance/quality control program to produce defensible data of known precision and accuracy. All quality control measures shall be assessed and evaluated on an on-going basis and quality control acceptance criteria shall be used to determine the validity of the data. All method specific quality control as prescribed in the method shall be followed. If quality control requirements are not included in the method, the permittee or designated laboratory shall follow the quality control requirements as prescribed in the Approved Edition (40 CFR Part 136) Standard Methods for the Examination of Water and Wastes, Sections 1020A and 1020B. General sampling protocol shall follow guidelines established in the

"Handbook for Sampling and Sample Preservation of Water and Wastewater, 1982 "U.S. Environmental Protection Agency. This publication is available from the National Technical Information Service (NTIS), Springfield, VA 22161, Phone number (800) 553-6847. Order by NTIS publication number PB-83-124503.

6. Flow Measurements

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the volume of monitored discharges. The devices shall be installed, calibrated, and maintained to insure that the accuracy of the measurements are consistent with the accepted capability of that type of device. Devices selected shall be capable of measuring flows with a maximum deviation of less than 10% from true discharge rates throughout the range of expected discharge volumes. Guidance in selection, installation, calibration and operation of acceptable flow measurement devices can be obtained from the following references:

- a. "A Guide to Methods and Standards for the Measurement of Water Flow, 1975," U.S. Department of Commerce, National Bureau of Standards. This publication is available from the National Technical Information Service (NTIS), Springfield, VA 22161, Phone number (800) 553-6847. Order by NTIS publication number COM-75-10683.
- b. "Flow Measurement in Open Channels and Closed Conduits, Volumes 1 and 2," U.S. Department of Commerce, National Bureau of Standards. This publication is available from the National Technical Service (NTIS), Springfield, VA, 22161, Phone number (800) 553-6847. Order by NTIS publication number PB-273 535.
- c. "NPDES Compliance Flow Measurement Manual," U.S. Environmental Protection Agency, Office of Water Enforcement. This publication is available from the National Technical Information Service (NTIS), Springfield, VA 22161, Phone number (800) 553-6847. Order by NTIS publication number PB-82-131178.

7. Prohibition for Tampering: Penalties

- a. LA R.S. 30:2025 provides for punishment of any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit.
- b. LA R.S. 30:2076.2 provides for penalties for any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non compliance.

8. Additional Monitoring by the Permittee

If the Permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 40 CFR Part 136 (See LAC 33:IX.4901) or, in the case of sludge use and disposal, approved under 40 CFR Part 136 (See LAC 33:IX.4901) unless otherwise specified in 40 CFR Part 503, or as specified in the permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the state administrative authority.

9. Averaging of Measurements

Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the state administrative authority in the permit.

10. Laboratory Accreditation

- a. LAC 33:i.Subpart 3, Chapters 45-59 provide requirements for an accreditation program specifically applicable to commercial laboratories, wherever located, that provide chemical analyses, analytical results, or other test data to the department, by contract or by agreement, and the data is:
 - (1) Submitted on behalf of any facility, as defined in R.S.30:2004;
 - (2) Required as part of any permit application;
 - (3) Required by order of the department;
 - (4) Required to be included on any monitoring reports submitted to the department;
 - (5) Required to be submitted by contractor
 - (6) Otherwise required by department regulations.

- b. The department laboratory accreditation program, Louisiana Environmental Laboratory Accreditation Program (LELAP) is designed to ensure the accuracy, precision, and reliability of the data generated, as well as the use of department-approved methodologies in generation of that data. Laboratory data generated by commercial environmental laboratories that are not (LELAP) accredited will not be accepted by the department. Retesting of analysis will be required by an accredited commercial laboratory.

Where retesting of effluent is not possible (i.e. data reported on DMRs for prior month's sampling), the data generated will be considered invalid and in violation of the LPDES permit.

- c. Regulations on the Louisiana Environmental Laboratory Accreditation Program and a list of labs that have applied for accreditation are available on the department website located under DIVISIONS → LABORATORY SERVICES at the following link:

<http://www.deq.louisiana.gov>

Questions concerning the program may be directed to (225) 219-9800.

SECTION D. REPORTING REQUIREMENTS

1. Facility Changes

The permittee shall give notice to the state administrative authority as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:

- a. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR 122.29(b); or
- b. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under LAC 33:IX.2703.A.1.
- c. For Municipal Permits. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to Section 301, or 306 of the CWA if it were directly discharging those pollutants; and any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit. In no case are any new connections, increased flows, or significant changes in influent quality permitted that will cause violation of the effluent limitations specified herein.

2. Anticipated Noncompliance

The permittee shall give advance notice to the state administrative authority of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

3. Transfers

This permit is not transferable to any person except after notice to the state administrative authority. The state administrative authority may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Clean Water Act or the Louisiana Environmental Quality Act. (See LAC 33:IX.2901; in some cases, modification or revocation and reissuance is mandatory.)

A permit may be transferred by the permittee to a new owner or operator only if the permit has been modified or revoked and reissued (under LAC 33:IX.2903. A.2.b), or a minor modification made (under LAC 33:IX.2905) to identify the new permittee and incorporate such other requirements as may be necessary under the Clean Water Act and the Louisiana Environmental Quality Act.

4. Monitoring Reports

Monitoring results shall be reported at the intervals and in the form specified in Part I or Part II of this permit.

The permittee shall submit properly completed Discharge Monitoring Reports (DMRs) on the form specified in the permit. Preprinted DMRs are provided to majors/92-500's and other designated facilities. Please contact the Permit Compliance Unit concerning preprints. Self-generated DMRs must be pre-approved by the Permit Compliance Unit prior to submittal. Self-generated DMRs are approved on an individual basis. Requests for approval of self-generated DMRs should be submitted to:

Supervisor, Permit Compliance Unit
Office of Environmental Compliance
Post Office Box 4312
Baton Rouge, LA 70821-4312

Copies of blank DMR templates, plus instructions for completing them, and EPA's LPDES Reporting Handbook are available at the department website located at:

<http://www.deq.louisiana.gov/portal/Default.aspx?tabid=2276>

5. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.

6. Requirements for Notification**a. Emergency Notification**

As required by LAC 33:I.3915, in the event of an unauthorized discharge that does cause an emergency condition, the discharger shall notify the hotline (DPS 24-hour Louisiana Emergency Hazardous Materials Hotline) by telephone at (225) 925-6595 (collect calls accepted 24 hours a day) immediately (a reasonable period of time after taking prompt measures to determine the nature, quantity, and potential off-site impact of a release, considering the exigency of the circumstances), but in no case later than one hour after learning of the discharge. (An emergency condition is any condition which could reasonably be expected to endanger the health and safety of the public, cause significant adverse impact to the land, water, or air environment, or cause severe damage to property.) Notification required by this section will be made regardless of the amount of discharge. Prompt Notification Procedures are listed in Section D.6.c. of these standard conditions.

A written report shall be provided within seven calendar days after the notification. The report shall contain the information listed in Section D.6.d. of these standard conditions and any additional information in LAC 33:I.3925.B.

b. Prompt Notification

As required by LAC 33:I.3917, in the event of an unauthorized discharge that exceeds a reportable quantity specified in LAC 33:I.Subchapter E, but does not cause an emergency condition, the discharger shall promptly notify the department within 24 hours after learning of the discharge. Notification should be made to the Office of Environmental Compliance, Surveillance Division Single Point of Contact (SPOC) in accordance with LAC 33:I.3923.

In accordance with LAC 33:I.3923, prompt notification shall be provided within a time frame not to exceed 24 hours and shall be given to the Office of Environmental Compliance, Surveillance Division Single Point of Contact (SPOC) as follows:

- (1) by the Online Incident Reporting screens found at <http://www3.deq.louisiana.gov/surveillance/irf/forms/>; or

- (2) by e-mail utilizing the Incident Report Form and instructions found at <http://www.deq.louisiana.gov/portal/Default.aspx?tabid=279>; or
 - (3) by telephone at (225) 219-3640 during office hours, or (225) 342-1234 after hours and on weekends and holidays.
- c. Content of Prompt Notifications. The following guidelines will be utilized as appropriate, based on the conditions and circumstances surrounding any unauthorized discharge, to provide relevant information regarding the nature of the discharge:
- (1) the name of the person making the notification and the telephone number where any return calls from response agencies can be placed;
 - (2) the name and location of the facility or site where the unauthorized discharge is imminent or has occurred, using common landmarks. In the event of an incident involving transport, include the name and address of the transporter and generator;
 - (3) the date and time the incident began and ended, or the estimated time of continuation if the discharge is continuing;
 - (4) the extent of any injuries and identification of any known personnel hazards that response agencies may face;
 - (5) the common or scientific chemical name, the U.S. Department of Transportation hazard classification, and the best estimate of amounts of any and all discharged pollutants;
 - (6) a brief description of the incident sufficient to allow response agencies to formulate their level and extent of response activity.
- d. Written Notification Procedures. Written reports for any unauthorized discharge that requires notification under Section D.6.a. or 6.b., or shall be submitted by the discharger to the Office of Environmental Compliance, Surveillance Division SPOC in accordance with LAC 33:IX.3925 within seven calendar days after the notification required by D.6.a. or 6.b., unless otherwise provided for in a valid permit or other department regulation. Written notification reports shall include, but not be limited to, the following information:
- (1) the name, address, telephone number, Agency Interest (AI) number (number assigned by the department) if applicable, and any other applicable identification numbers of the person, company, or other party who is filing the written report, and specific identification that the report is the written follow-up report required by this section;
 - (2) the time and date of prompt notification, the state official contacted when reporting, the name of person making that notification, and identification of the site or facility, vessel, transport vehicle, or storage area from which the unauthorized discharge occurred;
 - (3) date(s), time(s), and duration of the unauthorized discharge and, if not corrected, the anticipated time it is expected to continue;
 - (4) details of the circumstances (unauthorized discharge description and root cause) and events leading to any unauthorized discharge, including incidents of loss of sources of radiation, and if the release point is subject to a permit:
 - (a) the current permitted limit for the pollutant(s) released; and
 - (b) the permitted release point/outfall ID.
 - (5) the common or scientific chemical name of each specific pollutant that was released as the result of an unauthorized discharge, including the CAS number and U.S. Department of Transportation hazard classification, and the best estimate of amounts of any and all released pollutants (total amount of each compound expressed in pounds, including calculations);

- (6) a statement of the actual or probable fate or disposition of the pollutant or source of radiation and what off-site impact resulted;
- (7) remedial actions taken, or to be taken, to stop unauthorized discharges or to recover pollutants or sources of radiation.
- (8) Written notification reports shall be submitted to the Office of Environmental Compliance, Surveillance Division SPOC by mail or fax. The transmittal envelope and report or fax cover page and report should be clearly marked "**UNAUTHORIZED DISCHARGE NOTIFICATION REPORT.**"

Please see LAC 33:I.3925.B for additional written notification procedures.

- e. Twenty-four Hour Reporting. The permittee shall report any noncompliance which may endanger human health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within five days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and; steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance. The following shall be included as information which must be reported within 24 hours:
 - (1) Any unanticipated bypass which exceeds any effluent limitation in the permit (see LAC 33:IX.2701.M.3.b.);
 - (2) Any upset which exceeds any effluent limitation in the permit;
 - (3) Violation of a maximum daily discharge limitation for any of the pollutants listed by the state administrative authority in Part II of the permit to be reported within 24 hours (LAC 33:IX.2707.G.).

7. Other Noncompliance

The permittee shall report all instances of noncompliance not reported under Section D.4., 5., and 6., at the time monitoring reports are submitted. The reports shall contain the information listed in Section D.6.e.

8. Other Information

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the state administrative authority, it shall promptly submit such facts or information.

9. Discharges of Toxic Substances

In addition to the reporting requirements under Section D.1-8, all existing manufacturing, commercial, mining, and silvicultural dischargers must notify the Office of Environmental Services, Water Permits Division as soon as they know or have reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant:
 - i. listed at LAC 33:IX.7107, Tables II and III (excluding Total Phenols) which is not limited in the permit, if that discharge will exceed the highest of the following notification levels:
 - (1) One hundred micrograms per liter (100 µg/L);
 - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,4 -dinitro-phenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with LAC33:IX.2501.G.7; or
 - (4) The level established by the state administrative authority in accordance with LAC 33:IX.2707.F; or
 - ii. which exceeds the reportable quantity levels for pollutants at LAC 33:I. Subchapter E.

- b. That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant:
- i. listed at LAC 33:IX.7107, Tables II and III (excluding Total Phenols) which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
 - (1) Five hundred micrograms per liter (500 µg/L);
 - (2) One milligram per liter (1 mg/L) for antimony;
 - (3) Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with LAC 33:IX.2501.G.7; or
 - (4) The level established by the state administrative authority in accordance with LAC 33:IX.2707.F; or
 - ii. which exceeds the reportable quantity levels for pollutants at LAC 33:I. Subchapter E.

10. Signatory Requirements

All applications, reports, or information submitted to the state administrative authority shall be signed and certified.

a. All permit applications shall be signed as follows:

- (1) For a corporation - by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:
 - (a) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision making functions for the corporation; or,
 - (b) The manager of one or more manufacturing, production, or operating facilities, provided: the manager is authorized to make management decisions that govern the operation of the regulated facility, including having the explicit or implicit duty of making major capital investment recommendations and initiating and directing other comprehensive measures to ensure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and the authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.

NOTE: DEQ does not require specific assignments or delegations of authority to responsible corporate officers identified in Section D.10.a.(1)(a). The agency will presume that these responsible corporate officers have the requisite authority to sign permit applications unless the corporation has notified the state administrative authority to the contrary. Corporate procedures governing authority to sign permit applications may provide for assignment or delegation to applicable corporate positions under Section D.10.a.(1)(b) rather than to specific individuals.

- (2) For a partnership or sole proprietorship - by a general partner or the proprietor, respectively; or
 - (3) For a municipality, state, federal, or other public agency - by either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a federal agency includes:
 - (a) The chief executive officer of the agency, or
 - (b) A senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of EPA).
- b. All reports required by permits and other information requested by the state administrative authority shall be signed by a person described in Section D.10.a., or by a duly authorized representative of that person. A person is a duly authorized representative only if:
- (1) The authorization is made in writing by a person described in Section D.10.a. of these standard conditions:

- (2) The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company, (a duly authorized representative may thus be either a named individual or an individual occupying a named position; and,
 - (3) The written authorization is submitted to the state administrative authority.
- c. Changes to authorization. If an authorization under Section D.10.b. is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Section D.10.b. must be submitted to the state administrative authority prior to or together with any reports, information, or applications to be signed by an authorized representative.
 - d. Certification. Any person signing a document under Section D.10. a. or b. above, shall make the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

11. Availability of Reports

All recorded information (completed permit application forms, fact sheets, draft permits, or any public document) not classified as confidential information under R.S. 30:2030(A) and 30:2074(D) and designated as such in accordance with these regulations (LAC 33:IX.2323 and LAC 33:IX.6503) shall be made available to the public for inspection and copying during normal working hours in accordance with the Public Records Act, R.S. 44:1 et seq.

Claims of confidentiality for the following will be denied:

- a. The name and address of any permit applicant or permittee;
- b. Permit applications, permits, and effluent data.
- c. Information required by LPDES application forms provided by the state administrative authority under LAC 33:IX.2501 may not be claimed confidential. This includes information submitted on the forms themselves and any attachments used to supply information required by the forms.

SECTION E. PENALTIES FOR VIOLATIONS OF PERMIT CONDITION

1. Criminal

a. Negligent Violations

The Louisiana Revised Statutes LA. R. S. 30:2076.2 provides that any person who negligently violates any provision of the LPDES, or any order issued by the secretary under the LPDES, or any permit condition or limitation implementing any such provision in a permit issued under the LPDES by the secretary, or any requirement imposed in a pretreatment program approved under the LPDES is subject to a fine of not less than \$2,500 nor more than \$25,000 per day of violation, or by imprisonment for not more than 1 year, or both. If a conviction of a person is for a violation committed after a first conviction of such person, he shall be subject to a fine of not more than \$50,000 per day of violation, or imprisonment of not more than two years, or both.

b. Knowing Violations

The Louisiana Revised Statutes LA. R. S. 30:2076.2 provides that any person who knowingly violates any provision of the LPDES, or any permit condition or limitation implementing any such provisions in a permit issued under the LPDES, or any requirement imposed in a pretreatment program approved under

the LPDES is subject to a fine of not less than \$5,000 nor more than \$50,000 per day of violation, or imprisonment for not more than 3 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person, he shall be subject to a fine of not more than \$100,000 per day of violation, or imprisonment of not more than six years, or both.

c. Knowing Endangerment

The Louisiana Revised Statutes LA. R. S. 30:2076.2 provides that any person who knowingly violates any provision of the LPDES, or any order issued by the secretary under the LPDES, or any permit condition or limitation implementing any of such provisions in a permit issued under the LPDES by the secretary, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000, or by imprisonment for not more than 15 years, or both. A person which is an organization shall, upon conviction of violating this Paragraph, be subject to a fine of not more than one million dollars. If a conviction of a person is for a violation committed after a first conviction of such person under this Paragraph, the maximum punishment shall be doubled with respect to both fine and imprisonment.

d. False Statements

The Louisiana Revised Statutes LA. R. S. 30:2076.2 provides that any person who knowingly makes any false material statement, representation, or certification in any application, record, report, plan, or other document filed or required to be maintained under the LPDES or who knowingly falsifies, tampers with, or renders inaccurate, any monitoring device or method required to be maintained under the LPDES, shall, upon conviction, be subject to a fine of not more than \$10,000, or imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this Subsection, he shall be subject to a fine of not more than \$20,000 per day of violation, or imprisonment of not more than 4 years, or both.

2. Civil Penalties

The Louisiana Revised Statutes LA. R. S. 30:2025 provides that any person found to be in violation of any requirement of this Subtitle may be liable for a civil penalty, to be assessed by the secretary, an assistant secretary, or the court, of not more than the cost to the state of any response action made necessary by such violation which is not voluntarily paid by the violator, and a penalty of not more than \$32,500 for each day of violation. However, when any such violation is done intentionally, willfully, or knowingly, or results in a discharge or disposal which causes irreparable or severe damage to the environment or if the substance discharged is one which endangers human life or health, such person may be liable for an additional penalty of not more than one million dollars.

(PLEASE NOTE: These penalties are listed in their entirety in Subtitle II of Title 30 of the Louisiana Revised Statutes.)

SECTION F. DEFINITIONS

All definitions contained in Section 502 of the Clean Water Act shall apply to this permit and are incorporated herein by reference. Additional definitions of words or phrases used in this permit are as follows:

1. Clean Water Act (CWA) means the Clean Water Act (formerly referred to as the Federal Water Pollution Control Act or the Federal Water Pollution Control Act Amendments of 1972) Pub.L.92-500, as amended by Pub.L. 95-217, Pub.L. 95-576, Pub.L. 96-483 and Pub.L. 97-117, 33 U.S.C. 1251 et. seq.).
2. Accreditation means the formal recognition by the department of a laboratory's competence wherein specific tests or types of tests can be accurately and successfully performed in compliance with all minimum requirements set forth in the regulations regarding laboratory accreditation.
3. Administrator means the Administrator of the U.S. Environmental Protection Agency, or an authorized representative.

4. Applicable Standards and Limitations means all state, interstate and federal standards and limitations to which a discharge is subject under the Clean Water Act, including, effluent limitations, water quality standards of performance, toxic effluent standards or prohibitions, best management practices, and pretreatment standards under Sections 301, 302, 303, 304, 306, 307, 308 and 403.
5. Applicable water quality standards means all water quality standards to which a discharge is subject under the Clean Water Act.
6. Commercial Laboratory means any laboratory, wherever located, that performs analyses or tests for third parties for a fee or other compensation and provides chemical analyses, analytical results, or other test data to the department. The term commercial laboratory does not include laboratories accredited by the Louisiana Department of Health and Hospitals in accordance with R.S.49:1001 et seq.
7. Daily Discharge means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in terms of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the sampling day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the average measurement of the pollutant over the sampling day. Daily discharge determination of concentration made using a composite sample shall be the concentration of the composite sample.
8. Daily Maximum discharge limitation means the highest allowable "daily discharge".
9. Director means the U.S. Environmental Protection Agency Regional Administrator, or the state administrative authority, or an authorized representative.
10. Domestic septage means either liquid or solid material removed from a septic tank, cesspool, portable toilet, Type III marine sanitation device, or similar treatment works that receives only domestic sewage. Domestic septage does not include liquid or solid material removed from a septic tank, cesspool, or similar treatment works that receives either commercial wastewater or industrial wastewater and does not include grease removed from grease trap at a restaurant.
11. Domestic sewage means waste and wastewater from humans, or household operations that is discharged to or otherwise enters a treatment works.
12. Environmental Protection Agency or (EPA) means the U.S. Environmental Protection Agency.
13. Grab sample means an individual sample collected over a period of time not exceeding 15 minutes, unless more time is needed to collect an adequate sample, and is representative of the discharge.
14. Industrial user means a nondomestic discharger, as identified in 40 CFR 403, introducing pollutants to a publicly owned treatment works.
15. LEQA means the Louisiana Environmental Quality Act.
16. Louisiana Pollutant Discharge Elimination System (LPDES) means those portions of the Louisiana Environmental Quality Act and the Louisiana Water Control Law and all regulations promulgated under their authority which are deemed equivalent to the National Pollutant Discharge Elimination System (NPDES) under the Clean Water Act in accordance with Section 402 of the Clean Water Act and all applicable federal regulations.

17. Monthly Average, other than for fecal coliform bacteria, discharge limitations are calculated as the sum of all "daily discharge(s)" measured during a calendar month divided by the number of "daily discharge(s)" measured during that month. When the permit establishes monthly average concentration effluent limitations or conditions, and flow is measured as continuous record or with a totalizer, the monthly average concentration means the arithmetic average (weighted by flow) of all "daily discharge(s)" of concentration determined during the calendar month where C = daily discharge concentration, F = daily flow and n = number of daily samples; monthly average discharge =

$$\frac{C_1F_1 + C_2F_2 + \dots + C_nF_n}{F_1 + F_2 + \dots + F_n}$$

When the permit establishes monthly average concentration effluent limitations or conditions, and the flow is not measured as a continuous record, then the monthly average concentration means the arithmetic average of all "daily discharge(s)" of concentration determined during the calendar month.

The monthly average for fecal coliform bacteria is the geometric mean of the values for all effluent samples collected during a calendar month.

18. National Pollutant Discharge Elimination System (NPDES) means the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements, under Sections 307, 318, 402, and 405 of the Clean Water Act.
19. Severe property damage means substantial physical damage to property, damage to the treatment facilities that causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
20. Sewage sludge means a solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in a treatment works. Sewage sludge includes, but is not limited to, domestic septage; scum or solids removed in primary, secondary, or advanced wastewater treatment processes; portable toilet pumpings, type III marine sanitation device pumpings (33 CFR part 159); and a material derived from sewage sludge. Sewage sludge does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator or grit and screenings generated during preliminary treatment of domestic sewage in a treatment works.
21. Treatment works means any devices and systems used in the storage, treatment, recycling and reclamation of municipal sewage and industrial wastes of a liquid nature to implement Section 201 of the Clean Water Act, or necessary to recycle or reuse water at the most economical cost over the estimated life of the works, including intercepting sewers, sewage collection systems, pumping, power and other equipment, and their appurtenances, extension, improvement, remodeling, additions, and alterations thereof. (See Part 212 of the Clean Water Act)
22. For fecal coliform bacteria, a sample consists of one effluent grab portion collected during a 24-hour period at peak loads.
23. The term MGD shall mean million gallons per day.
24. The term mg/L shall mean milligrams per liter or parts per million (ppm).
25. The term ug/L shall mean micrograms per liter or parts per billion (ppb).
26. The term ng/L shall mean nanograms per liter or parts per trillion (ppt).

27. Weekly average, other than for fecal coliform bacteria, is the highest allowable arithmetic mean of the daily discharges over a calendar week, calculated as the sum of all "daily discharge(s)" measured during a calendar week divided by the number of "daily discharge(s)" measured during that week. When the permit establishes weekly average concentration effluent limitations or conditions, and flow is measured as continuous record or with a totalizer, the weekly average concentration means the arithmetic average (weighted by flow) of all "daily discharge(s)" of concentration determined during the calendar week where C = daily discharge concentration, F = daily flow and n = number of daily samples; weekly average discharge

$$= \frac{C_1F_1 + C_2F_2 + \dots + C_nF_n}{F_1 + F_2 + \dots + F_n}$$

When the permit establishes weekly average concentration effluent limitations or conditions, and the flow is not measured as a continuous record, then the weekly average concentration means the arithmetic average of all "daily discharge(s)" of concentration determined during the calendar week.

The weekly average for fecal coliform bacteria is the geometric mean of the values for all effluent samples collected during a calendar week.

28. Sanitary Wastewater Term(s):

- a. 3-hour composite sample consists of three effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) over the 3-hour period and composited according to flow, or a sample continuously collected in proportion to flow over the 3-hour period.
- b. 6-hour composite sample consists of six effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) over the 6-hour period and composited according to flow, or a sample continuously collected in proportion to flow over the 6-hour period.
- c. 12-hour composite sample consists of 12 effluent portions collected no closer together than one hour over the 12-hour period and composited according to flow, or a sample continuously collected in proportion to flow over the 12-hour period. The daily sampling intervals shall include the highest flow periods.
- d. 24-hour composite sample consists of a minimum of 12 effluent portions collected at equal time intervals over the 24-hour period and combined proportional to flow or a sample continuously collected in proportion to flow over the 24-hour period.

I. Introduction

- Comment 1: Commenter has "concerns about discharging partially treated wastewater into wetlands".
Response 1: The application submitted to the Department does not indicate the intentions of the permittee to discharge *partially* treated wastewater into wetlands. The application indicates the permittee will treat sanitary wastewater and discharge said treated sanitary wastewater into the Guste Island Wetlands. The Department has issued Louisiana Pollutant Discharge Elimination System (LPDES) Permit LA0120243 to the facility authorizing the discharge of treated sanitary wastewater in accordance with the requirements set forth in the permit.

II. Guste Island's Non-Wetland Conditions Raises Serious Questions About Its Appropriateness as a Wastewater Assimilation Site

- Comment 2: The Guste Island assimilation wetlands are not wetlands anymore.
Response 2: The term *fastland* was used in the Use Attainability Analysis (UAA). The term *fastland* is a term defined by the Louisiana Department of Natural Resources (LDNR) in LAC 43:1.Chapter 7 and used with regard to coastal zone management. Please note that Guste Island applied for an LPDES permit and is subject to the regulation of the LAC 33: Part IX. Water Quality. Whether or not the facility has applied for a determination with regard to coastal use permit is not relevant to the LPDES permitting process. *Wetlands* is defined in LAC 33:IX.107 and 1105 as "those areas that are inundated or saturated by surface or groundwater at a frequency and duration sufficient to support, and that under normal circumstances do support, a prevalence of vegetation typically adapted for life in saturated soil conditions". Based on the U.S. Department of Agriculture's Natural Resources Conservation Service soil map of the site, the soils of the site are hydric soils. Plants identified in the species composition of vegetation in the Use Attainability Analysis for the Guste Island site are wetland plants. The site meets the definition of *Wetlands* of LAC 33:IX.107 and 1105. This determination is further supported by the determination of the area as a wetland by the U.S. Army Corp of Engineers on December 11, 2007.
- Comment 3: If the receiving wetland is not, in fact, a wetland in most respects, how can LDEQ conclude that the "wetland" will, in fact, uptake the nutrients.
Response 3: As indicated in Response 2 (above), the area of the discharge is, in fact, a wetland and is consistent with the definition of *wetlands* of LAC 33:IX.107 and 1105. This determination is further supported by the determination made by the U.S. Army Corp of Engineers. Scientific studies conducted in Louisiana have documented that wetlands have the capability to assimilate nutrients found in sanitary wastewater.
- Comment 4: Has water been flooded into the area during the last two years?
Response 4: To the knowledge of the Department, the applicant has not provided any information to indicate that the wetland has been flooded in the last two years.

Comment 5: Has wetland vegetation grown?

Response 5: The proposed wetland assimilation area supports wetland vegetation. Species of plants identified in the species composition of vegetation in the Use Attainability Analysis for the Guste Island site are wetland plants. The permittee is required to supplement the existing wetland vegetation by additional planting of wetland plants to provide additional enhancement of the wetland. Part II, Section B of the permit has been amended requiring supplemental vegetation plantings.

Comment 6: Does LDEQ expect the newly planted vegetation (if, indeed, it has been planted) to make the area uptake like a wetland?

Response 6: The area is a wetland and the Department expects the existing vegetation to uptake nutrients as has been documented in other wetland assimilation projects. The addition of newly planted vegetation will enhance the uptake of nutrients in the wetland as the plants mature. If the performance of this or other assimilation projects do not meet the expectation, the issues will be addressed through the reopener clause.

Comment 7: Is the wastewater discharge in fact the "flooding" that the UAA discusses?

Response 7: The UAA does not specify the source of flooding. It is anticipated that the discharge, the ebb and flow of tide, wind-driven high water from Lake Pontchartrain, and precipitation will contribute to the water in the wetland and to restoration of the hydrology of the area.

Comment 8: What is the basis for calculations for assimilation of nutrients in the wetland?

Response 8: The loading rates for the wetland were calculated in accordance with the Volume 3 of the Louisiana Water Quality Management Plan (WQMP), *Permitting Guidance Document for Implementing Louisiana Surface Water Quality Standards*.

Comment 9: The Statement of Basis is unclear regarding the Guste Island Restoration Plan and the plan has not been updated.

Response 9: Guste Island submitted the Guste Island Restoration Plan to the Department. The plan is not a requirement of the permit. Part II, Section B of the permit has been amended requiring supplemental vegetation plantings. The wetland system monitoring requirements are set forth in Part II, Section B of the permit. The required supplemental plantings is subject to the monitoring required by Part II, Section B of the permit. The permittee is also required to provide an annual update on the status of the supplemental plantings in the Annual Wetland Monitoring Report.

Comment 10: If the site has been fully converted into an agricultural and development site since the 1960s. How long will it take, if ever, to re-convert the wetlands?

Response 10: The assimilation area currently has characteristics which defines it as wetlands and is consistent with the definition of *wetlands* of LAC 33:IX.107 and 1105. The project will significantly enhance the natural progression of the area back to productive wetlands.

Comment 11: What will happen to excess nutrients that come from the wastewater?

Response 11: The facility proposed to treat the wastewater and discharge the treated wastewater into the wetland assimilation area. The nutrients will be assimilated in the wetland assimilation area. The size of the wetland and concentration of nutrients introduced are calculated to obtain maximum uptake. Monitoring will assure this is occurring.

Comment 12: The UAA should be reworked using data from a fastland or constructed wetland.

Response 12: The area has been determined to meet the criteria of a wetland and is consistent with the definition of *wetlands* of LAC 33:IX.107 and 1105; therefore, the data used in support of the analysis in UAA is appropriate.

Comment 13: The planned use of Guste Island as a mitigation area is improper and unworkable as part of the project.

Response 13: The Department does not approve wetland mitigation banks. Therefore, comments related to the potential future use of the location as a mitigation bank are not specifically relevant to issuance of and compliance with this water discharge permit.

Comment 14: Neither the UAA nor the Statement of Basis provides support for the choice of a reference area.

Response 14: The Louisiana Water Quality Management Plan defines the reference area as a wetland area that is nearby and is similar to the discharge area, but is not affected by effluent addition. The reference area and discharge area were determined through the feasibility and baseline studies as required by the Louisiana Water Quality Management Plan. The Reference Area will not receive any of the effluent from the sanitary discharge. The monitoring that will be conducted as required by Part II, Section B of the permit will allow for comparison of the wetland assimilation area and the reference or control area. The permit has been modified to further delineate the reference or control area.

III. TSS Limits Should Be Set at Secondary Treatment Levels.

Comment 15: TSS limits should be set at secondary treatment levels.

Response 15: The commenter contends that the secondary treatment limits for TSS should be set at the secondary treatment level of 30 mg/L/45mg/L in the absence of proof that the Guste Island ponds cannot meet secondary treatment limits. In the Federal Register Vol. 42 No. 195 (October 7, 1977 p.51661) the secondary treatment limitation for oxidation ponds was amended "due to TSS being primarily algae". In the Federal Register Vol. 49, No. 184 (September 20, 1984 Appendix B), the thirty (30) day average TSS for wastewater treatment ponds was set for the various states based on temperatures in the different areas. The 30-day average for wastewater treatment ponds in Louisiana was set at 90 mg/l. Furthermore, LAC 33:IX.711.D. sets the limits for treatment for facilities utilizing trickling filters or oxidation ponds. LAC 33:IX.711.D.2 specifically sets the limits for new oxidation ponds as 30 mg/L BOD and 90 mg/L TSS. The facility has a new 2-cell oxidation pond. Therefore, the limitations for BOD and TSS in the permit for the discharge from the oxidation pond have been properly set at 30 mg/L BOD and 90 mg/L TSS.

Comment 16: "A well-designed and properly operated lagoon system" can meet secondary treatment limits of 30/45 for TSS. The Town of Roseland uses a lagoon system "similar to the one proposed for Guste Island" and it consistently meets the TSS limits more stringent than 30/45.

Response 16: While the Town of Roseland and Guste Island both utilize a lagoon system for the treatment of sanitary wastewater, to state that the systems are "similar" for comparison is not appropriate. The Roseland treatment system is a Lemtec Modular system consisting of a three-cell lagoon. The first cell is an aerated cell; the second cell contains two aspirators and partially covered with a modular grid; and the third cell is used for polishing the effluent with a fixed film biological reactor. The effluent is disinfected with chlorine and discharged directly into the receiving stream. The Guste Island facility consists of a two-cell facultative lagoon with a 25-180 day retention time. The effluent is then disinfected with chlorine and discharged to the assimilation area. The nutrients remaining in the Roseland discharge may result in eutrophic conditions in the receiving stream; nutrients remaining in the Guste Island discharge will be assimilated in the wetland. To say that these systems are similar in nature and operation and are able to meet the same limitation is not appropriate.

IV. The Guste Island Permit Should Have Nitrogen and Phosphorus Limits, as Well as Ammonia Limits.

Comment 17: DEQ is required to limit nitrogen, phosphorus, and ammonia because regulations require limits for pollutants that may cause or contribute to an excursion above any water quality standard.

Response 17: Currently, Louisiana does not have a state water quality standard for nitrogen, phosphorus, and ammonia. Water quality standards are in the development stage and will be addressed through the reopener clause of the permit if necessary.

Comment 18: The uptake of nitrogen and phosphorus from the restoration project might be less than levels experienced in other wetland assimilation projects.

Response 18: DEQ will require monitoring of nitrogen and phosphorus at the pumping station at the High Bridge Canal until removal of the levee. The nutrients reported at this location will be compared to the levels in the control area.

Comment 19: The permit should include limitations for ammonia.

Response 19: Ammonia is a component of the total nitrogen measurement. Reporting of total nitrogen is already required by the permit. However, DEQ has amended the permit to include reporting of ammonia at the pond discharge and at the High Bridge Canal to measure uptake and to compare to the ambient levels in the control site.

V. LDEQ Must Ensure that Problems Occurring at the Hammond Assimilation Site Do Not Recur Here.

Comment 20: LDEQ must ensure that problems occurring at the Hammond Assimilation site do not recur here.

Response 20: As in the case of problems experienced at Hammond, the DEQ Enforcement Division will respond to any violation of permit parameters.

Comment 21: The proposed Guste Island permit will include discharges formerly handled by the Southeastern Louisiana Water & Sewer Company (SELA), and SELA will apparently still operate the collection system for the discharges it will feed into Guste Island.

Response 21: The addition of sanitary wastewater from a de-commissioned SELA facility will have no adverse effect on the treatment capabilities of the Guste Island facility. The LPDES permit issued to the Guste Island facility sets forth the requirements for the discharge of treated sanitary wastewater. Although SELA maintains the collection system, the Department maintains regulatory enforcement over all discharges to waters of the state, including enforcement over illicit discharges, leaks, and infiltration that may occur by companies not possessing an LPDES permit.

Comment 22: Tulane referred to an incident related inspection in January 2007 due to "terrible odors" from a lift station.

Response 22: The inspection in response to the reported incident revealed that there were no odors at the time of inspection and that the lift station was sealed to prevent the escape of odors.

Comment 23: There is a lack of clear guidance for the criteria for site assessment.

Response 23: The approval process for wetland assimilation of nutrient rich discharges is set forth in the Volume 3 of the Louisiana Water Quality Management Plan (WQMP) *Permitting Guidance Document for Implementing Louisiana Surface Water Quality Standards*. The approval process includes a feasibility assessment of the site, and a baseline study of the wetland that includes the discharge area and the reference area. The Department will continue to review the WQMP periodically and will proceed in review of criteria for site assessment for wetland assimilation projects and make any updates to the WQMP as deemed necessary.

Comment 24: Commenter expresses concern that projects are altered by "politics and real-life impediments".

Response 24: Changes and impediments arise during the development of many projects. As such, the Department reviews all permit monitoring requirements and reports, as well as, modification requests to ensure that the effectiveness of the project is maximized while impacts to the environments are minimized. The Guste Island project will produce a positive outcome by enhancement of a wetland which was degraded by man's activities.

VI. LDEQ Must Address Antidegradation Concerns.

Comment 25: The Lower Tchefuncte River is impaired for organic enrichment/low DO, pathogen indicators, and mercury; therefore, LDEQ must address antidegradation concerns.

Response 25: The facility proposes to discharge from the oxidation pond into the Guste Island Wetlands. The discharge must travel through the Guste Island Wetlands and several miles through canals prior to reaching the Lower Tchefuncte River. It is anticipated that the wetland will assimilate nutrients from the discharge and therefore should not cause or

contribute to the organic enrichment/low DO problems of the Lower Tchefuncte. The effluent will be chlorinated prior to discharge to the wetlands and therefore should not cause or contribute to the pathogen indicators impairment. The department does not anticipate the discharge of mercury in treated sanitary wastewater from a residential area and therefore should not cause or contribute to the mercury impairment. The Department determined that the discharge will not affect the existing uses of the Lower Tchefuncte River. Wetland enhancement projects such as Guste Island are very compatible with the agency's antidegradation policies. This project will benefit the defined wetland area on the north shore of Lake Pontchartrain and thus contribute to the enhancement of water quality in the Lake itself.

STATEMENT OF BASIS ADDENDUM

as required by LAC 33:IX.3109, for draft **Louisiana Pollutant Discharge Elimination System Permit No. LA0120243; AI 122552; PER20040001** to discharge to waters of the **State of Louisiana** as per LAC 33:IX.2311.

The **permitting authority** for the Louisiana Pollutant Discharge Elimination System (LPDES) is:

Louisiana Department of Environmental Quality
Office of Environmental Services
P. O. Box 4313
Baton Rouge, Louisiana 70821-4313

I. THE APPLICANT IS:

Guste Island Utility Company
Guste Island Wetland Assimilation Project
845 Galvez Street
Mandeville, LA 70448

II. PREPARED BY: Eura DeHart

DATE PREPARED: December 27, 2007

III. PERMIT ACTION: Issue LPDES permit LA0120243, AI 122552; PER20040001

Revised LPDES application received: February 6, 2006

IV. CHANGES TO THE PERMIT:

In response to comments received during the public comment period for the draft permit, the following changes to the permit have been made:

- A. Added a report requirement for ammonia to the effluent limitations;
- B. Added the location of the control area;
- C. Added a requirement for measuring height of the planted trees in the assimilation area;
- D. Added requirements for supplemental plantings; and
- E. Added monitoring for total nitrogen, total phosphorus, and ammonia at High Bridge Canal.

**WETLAND
MONITORING
&
REPORTING
REQUIREMENT
FORMS**

**Wetland Monitoring & Reporting Requirements
Due each year on the effective day of the permit**

**LOUISIANA POLLUTANT DISCHARGE
ELIMINATION SYSTEM
(LPDES)**

Wetland System Monitoring Requirement

for

**Guste Island Utilities Company
Guste Island Wetland Assimilation Project**

Permit Number: LA0120243

Agency Interest Number: AI 122552

Activity Number: PER20040001

**Wetland Monitoring & Reporting Requirements
Due each year from the effective date of the permit**

In the event that a permit is not reissued in a timely manner, the Annual Wetland Monitoring Report shall be submitted for the years following the expiration date of the permit and shall be due on the effective day of this permit, until a new permit is issued

Permit Year: 1 2 3 4 5
(circle one)

Date: _____

ANNUAL WETLAND MONITORING & REPORTING REQUIREMENTS
 Due each year from the effective date of the permit

Guste Island Utilities Company
 Guste Island Wetland Assimilation Project
 845 Galvez Street
 Mandeville, LA 70448

PERMIT NUMBER: LA0120243
 AGENCY INTEREST NUMBER: AI 122552
 ACTIVITY NUMBER: PER20040001

GROWTH STUDIES – STEM GROWTH (Flora)

PARAMETER	GROWTH STUDIES – STEM GROWTH (FLORA)					
	Wastewater Management Area (g/m ² /yr)			Control Area (g/m ² /yr)		
Treatment Area	UAA Overall Average	Current Overall Average	Difference ¹	UAA Overall Average	Current Overall Average	Difference ¹
Treatment Area 1						
Treatment Area 2						
Treatment Area 3						
Control Area 1						
Control Area 2						

¹ The difference in the UAA value and the Current value shall be indicated by NO INCREASE = 0, INCREASE = 1, or DECREASE = 2.

METAL ANALYSIS (Surface Water)

PARAMETER	METAL ANALYSIS (Surface Water)												ANOVA Significant Difference ² (p=0.05) YES or NO		
	Wastewater Assimilation Area						Control Area								
	UAA Average (mg/L)			Current Average (mg/L)			UAA Average (mg/L)			Current Average (mg/L)				Difference ¹	
	1	2	3	1	2	3	1	2	1	2	3				
Magnesium (Mg)															
Lead (Pb)															
Cadmium (Cd)															
Chromium (Cr)															
Copper (Cu)															
Zinc (Zn)															
Iron (Fe)															
Nickel (Ni)															
Silver (Ag)															
Selenium (Se)															

¹ The difference in the UAA value and the current value shall be indicated by NO INCREASE=0, INCREASE=1, DECREASE=2.

² Analysis of Variance (ANOVA), a significant difference (p=0.05) between the wastewater assimilation area and the control area shall be indicated by YES or NO.

NUTRIENT ANALYSIS I (Surface Water)

PARAMETER	NUTRIENT ANALYSIS I (Surface Water)										ANOVA Significant Difference ² (p=0.05) YES or NO	
	Wastewater Assimilation Area					Control Area						
	UAA Average (mg/L)		Current Average (mg/L)		Difference ¹	UAA Average (mg/L)		Current Average (mg/L)		Difference ¹		
	1	2	3	1		2	3	1	2			
Total Kjeldahl Nitrogen (TKN)												
Total Phosphorus (TP)												

¹ The difference in the UAA value and the current value shall be indicated by NO INCREASE=0, INCREASE=1, and DECREASE=2.

² Analysis of Variance (ANOVA), a significant difference (p=0.05) between the wastewater assimilation area and the control area shall be indicated by YES or NO.

NUTRIENT ANALYSIS II (Surface Water)

PARAMETER	NUTRIENT ANALYSIS II (Surface Water)										ANOVA Significant Difference ² (p=0.05) YES or NO	
	Wastewater Assimilation Area					Control Area						
	UAA Average (mg/L)		Current Average (mg/L)		Difference ¹	UAA Average (mg/L)		Current Average (mg/L)		Difference ¹		
	1	2	3	1		2	3	1	2			
Ammonia (NH3-N)												
Nitrite Nitrogen (NO2-N)												
Nitrate Nitrogen (NO3-N)												
Phosphate (PO ₄ -P)												

¹ The difference in the UAA value and the current value shall be indicated by NO INCREASE=0, INCREASE=1, DECREASE=2.

² Analysis of Variance (ANOVA), a significant difference (p=0.05) between the wastewater assimilation area and the control area shall be indicated by YES or NO.

FOURTH YEAR WETLAND MONITORING & REPORTING REQUIREMENTS

Summary Sheet

Due four (4) years from the effective date of the permit

Guste Island Utilities Company
 Guste Island Wetland Assimilation Project
 845 Galvez Street
 Mandeville, LA 70448

PERMIT NUMBER: LA0120243
 AGENCY INTEREST NUMBER: AI 122552
 ACTIVITY NUMBER: PER20040001

SPECIES CLASSIFICATION (Flora)

PARAMETERS		SPECIES CLASSIFICATION										Difference
		UAA or Previous Classification (year)					CURRENT					
Area	Species	No.	Relative Density	Relative Dominance	Relative Frequency	Importance Value	No.	Relative Density	Relative Dominance	Relative Frequency	Importance Value	
Treatment Area 1												
Treatment Area 2												
Treatment Area 3												
Control Area 1												
Control Area 2												

¹ The difference in the UAA value and the Current value shall be indicated by NO INCREASE = 0, INCREASE = 1, or DECREASE = 2.

METAL ANALYSIS (Flora)

PARAMETER	METAL ANALYSIS (Flora)										ANOVA Significant Difference ² (p=0.05) YES or NO			
	Wastewater Assimilation Area					Control Area								
	UAA Average (mg/L)			Current Average (mg/L)		UAA Average (mg/L)		Current Average (mg/L)						
	1	2	3	1	2	3	1	2	1	2				
Magnesium (Mg)														
Lead (Pb)														
Cadmium (Cd)														
Chromium (Cr)														
Copper (Cu)														
Zinc (Zn)														
Iron (Fe)														
Nickel (Ni)														
Silver (Ag)														
Selenium (Se)														

¹ The difference in the UAA value and the current value shall be indicated by NO INCREASE=0, INCREASE=1, DECREASE=2.

² Analysis of Variance (ANOVA), a significant difference (p=0.05) between the wastewater assimilation area and the control area shall be indicated by YES or NO.

METAL ANALYSIS (Sediment)

PARAMETER	METAL ANALYSIS (Sediment)										ANOVA Significant Difference ² (p=0.05) YES or NO		
	Wastewater Assimilation Area					Control Area						Difference ¹	
	UAA Average (mg/L)		Current Average (mg/L)		Difference	UAA Average (mg/L)		Current Average (mg/L)		Difference			
	1	2	3	1		2	3	1	2			3	
Magnesium (Mg)													
Lead (Pb)													
Cadmium (Cd)													
Chromium (Cr)													
Copper (Cu)													
Zinc (Zn)													
Iron (Fe)													
Nickel (Ni)													
Silver (Ag)													
Selenium (Se)													
Mercury (Hg)													
Arsenic (As)													

¹ The difference in the UAA value and the current value shall be indicated by **NO INCREASE=0, INCREASE=1, DECREASE=2.**

² Analysis of Variance (ANOVA), a significant difference (p=0.05) between the wastewater assimilation area and the control area shall be indicated by YES or NO.

NUTRIENT ANALYSIS I (Flora)

PARAMETER	NUTRIENT ANALYSIS I (Flora)										ANOVA Significant Difference ² (p=0.05) YES or NO	
	Wastewater Assimilation Area					Control Area						
	UAA Average (mg/L)		Current Average (mg/L)		Difference ¹	UAA Average (mg/L)		Current Average (mg/L)		Difference ¹		
	1	2	3	1		2	3	1	2			
Total Kjeldahl Nitrogen (TKN)												
Total Phosphorus (TP)												

¹ The difference in the UAA value and the current value shall be indicated by NO INCREASE=0, INCREASE=1, and DECREASE=2.

² Analysis of Variance (ANOVA), a significant difference (p=0.05) between the wastewater assimilation area and the control area shall be indicated by YES or NO.

NUTRIENT ANALYSIS I (Sediment)

PARAMETER	NUTRIENT ANALYSIS I (Sediment)										ANOVA Significant Difference ² (p=0.05) YES or NO						
	Wastewater Assimilation Area					Control Area											
	UAA Average (mg/L)			Current Average (mg/L)		Difference ¹		UAA Average (mg/L)				Current Average (mg/L)		Difference ¹			
	Assimilation Area			Assimilation Area		Assimilation Area		Control Area				Control Area		Control Area			
Total Kjeldahl Nitrogen (TKN)	1	2	3	1	2	3	1	2	1	2							
Total Phosphorus (TP)																	

¹ The difference in the UAA value and the current value shall be indicated by **NO INCREASE=0, INCREASE=1, and DECREASE=2.**

² Analysis of Variance (ANOVA), a significant difference (p=0.05) between the wastewater assimilation area and the control area shall be indicated by YES or NO.

NUTRIENT ANALYSIS II (Sediment)

PARAMETER	NUTRIENT ANALYSIS II (Sediment)										ANOVA Significant Difference ² (p=0.05) YES or NO	
	Wastewater Assimilation Area					Control Area						
	UAA Average (mg/L)		Current Average (mg/L)		Difference ¹	UAA Average (mg/L)		Current Average (mg/L)		Difference ¹		
	1	2	3	1		2	3	1	2			
Ammonia (NH3-N)												
Nitrite Nitrogen (NO2-N)												
Nitrate Nitrogen (NO3-N)												
Phosphate (PO ₄ -P)												

¹ The difference in the UAA value and the current value shall be indicated by NO INCREASE=0, INCREASE=1, DECREASE=2.

² Analysis of Variance (ANOVA), a significant difference (p=0.05) between the wastewater assimilation area and the control area shall be indicated by YES or NO.

OTHER PARAMETERS (Surface Water)

PARAMETER	OTHER PARAMETERS (Surface Water)										ANOVA Significant Difference ² (p=0.05) YES or NO	
	Wastewater Assimilation Area					Control Area						
	UAA Average (mg/L)		Current Average (mg/L)		Difference ¹	UAA Average (mg/L)		Current Average (mg/L)		Difference ¹		
	Assimilation Area	Assimilation Area	Assimilation Area	Assimilation Area		Control Area	Control Area	Control Area	Control Area			
Biochemical Oxygen Demand (BOD ₅)	1	2	3	1	2	3	1	2	1	2		
Total Suspended Solids (TSS)												
pH												
Dissolved Oxygen (DO)												

¹ The difference in the UAA value and the current value shall be indicated by NO INCREASE=0, INCREASE=1, DECREASE=2.

² Analysis of Variance (ANOVA), a significant difference (p=0.05) between the wastewater assimilation area and the control area shall be indicated by YES or NO.

7004 1160 0003 2558 9917

U.S. Postal Service™
CERTIFIED MAIL™ RECEIPT
(Domestic Mail Only; No Insurance Coverage Provided)

For delivery information visit our website at www.usps.com

OFFICIAL USE

Kelly J. McHugh, President
Guste Island Utility Company
Guste Island Wetland Assimilation Project
845 Galvez Street
Mandeville, LA 70448

Sent To

Street, Apt. No.,
or PO Box No.
City, State, ZIP+4

PS Form 3800, June 2002

See Reverse for Instructions