

DRAFT - DISCHARGE UPDATE REPORT

Project: Temple-Inland Bogalusa Mill
Project Location: Bogalusa, Louisiana
Report Prepared By: Ed Cote
Date: September 2, 2011
Status of Report: Complete as of 9:00 AM, September 3 pending additional analyses

Weather Conditions: AM: fair/sunny PM: fair/sunny
Temperature: Max. 77°F
Cloud Cover: (Yes) (No)
Precipitation: (Yes) (No)

Discharge:
Beginning Time: Continuous
Ending Time: _____
Discharge Stoppage: No

Reason for Stoppage:
Description:

Activities, Remarks:

- Outfall monitoring was conducted in accordance with approved plan
- Middle gate lowered at 5:03PM. Initial flow set at 0.68 MGD.
- pH of discharge was within acceptable range
- ARCADIS assisted Temple-Inland with weir adjustments to maintain target flow
- ISCO bubbler flowmeters were operational on all three weirs

Problems/Deficiencies/Corrective Actions:

- None

Samples Taken / Results:

- Samples collected per frequencies indicated in Table 1 of approved Discharge Plan and results (to time indicated in above status) presented in attached table.

Calibration Records on Field Testing Equipment

- Outfall online pH and conductivity meters calibrated by Temple-Inland
- EBS sampling meters calibrated prior to start of discharge

Oversight/Visitors

- LDEQ representatives on site
- ISCO flow meter vendor representative
- EBS Sampling Laboratory