

DRAFT - DISCHARGE UPDATE REPORT

Project: Temple-Inland Bogalusa Mill
Project Location: Bogalusa, Louisiana
Report Prepared By: Ed Cote
Date: September 4, 2011
Status of Report: Complete as of 16:00 on September 4, 2011 pending additional analysis

Weather Conditions: AM: windy/rainy PM: windy/rainy
Temperature: Max. 78°F
Cloud Cover: (Yes) Tropical Storm Lee
Precipitation: (Yes)

Discharge:
Beginning Time: Continuous
Ending Time: _____
Discharge Stoppage: No _____

Reason for Stoppage:
Description:

Activities, Remarks:

- Outfall monitoring was conducted in accordance with approved plan
- Discharging through west and middle gates
- pH of discharge was within acceptable range
- ARCADIS assisted Temple-Inland with weir adjustments to maintain target flow

Problems/Deficiencies/Corrective Actions:

- None

Samples Taken / Results:

- Samples collected per frequencies indicated in Table 1 of approved Discharge Plan and results (to time indicated in above status) presented in attached table.

Calibration Records on Field Testing Equipment

- Outfall online pH and conductivity meters calibrated by Temple-Inland
- EBS sampling meters calibrated prior to start of discharge

Oversight/Visitors

- LDEQ representatives on site

- ISCO flow meter vendor representative
- EBS Sampling Laboratory