

## DRAFT - DISCHARGE UPDATE REPORT

**Project:** Temple-Inland Bogalusa Mill  
**Project Location:** Bogalusa, Louisiana  
**Report Prepared By:** Ed Cote  
**Date:** September 5, 2011  
**Status of Report:** Complete as of 16:00 on September 5, 2011

**Weather Conditions:** AM: windy/rainy PM: windy/light rain  
**Temperature:** Max. 75°F  
**Cloud Cover:** (Yes) Tropical Storm Lee  
**Precipitation:** (Yes)

**Discharge:**  
**Beginning Time:** Continuous  
**Ending Time:** \_\_\_\_\_  
**Discharge Stoppage:** No \_\_\_\_\_

**Reason for Stoppage:**  
**Description:**

### Activities, Remarks:

- Outfall monitoring was conducted in accordance with approved plan
- Discharging through west and middle gates
- pH of discharge was within acceptable range
- DOURLs and Micro exam at ASB MidPoint and Effluent continue to show good activity and BOD conversion
- Nutrient feed rate is currently at ~300 gpd. MicroStar bioaugmentation cultures continue to be added at 100 pound per day via the two BAC units

### Problems/Deficiencies/Corrective Actions:

- None

### Samples Taken / Results:

- Samples collected per frequencies indicated in Table 1 of approved Discharge Plan and results (to time indicated in above status) presented in attached table.

### Calibration Records on Field Testing Equipment

- Outfall online pH and conductivity meters calibrated by Temple-Inland
- EBS sampling meters calibrated prior to start of discharge

**Oversight/Visitors**

- LDEQ representatives on site
- EBS Sampling Laboratory