

Title 33
ENVIRONMENTAL QUALITY
Part XI. Underground Storage Tanks

Chapter 1. Program Applicability and Definitions

§101. Applicability

A. ...

B. Exclusions. The following UST systems are excluded from the requirements of these regulations: The owner or operator must provide documentation upon request for any exclusion claimed.

1. ~~a~~Any UST system holding hazardous wastes listed or identified in the Louisiana Department of Environmental Quality's Hazardous Waste Regulations or a mixture of such hazardous waste and other regulated substances is excluded from the requirements of these regulations;

2. ~~a~~Any wastewater treatment tank system that is part of a wastewater treatment facility regulated under Section 402 or 307(b) of the Clean Water Act is excluded from the requirements of these regulations;

3. ~~e~~Equipment or machinery that contains regulated substances for operational purposes such as hydraulic lift tanks and electrical equipment tanks is excluded from the requirements of these regulations;

4. ~~a~~Any UST system whose capacity is 110 gallons or less is excluded from the requirements of these regulations;

5. ~~a~~Any UST system that has never contained more than a de minimis concentration of regulated substances is excluded from the requirements of these regulations; ~~and~~

6. ~~a~~Any emergency spill or overflow containment UST system that is expeditiously emptied after use is excluded from the requirements of these regulations.

C. – C.2.b. ...

AUTHORITY NOTE: Promulgated in accordance with R.S. 30:2001 et seq.

HISTORICAL NOTE: Promulgated by the Department of Environmental Quality, Office of Solid and Hazardous Waste, Underground Storage Tank Division, LR 16:614 (July 1990), amended LR 17:658 (July 1991), LR 18:727 (July 1992), amended by the Office of Environmental Assessment, Environmental Planning Division, LR 29:**.