

Editor's Note: A portion of this Rule, which was published on pages 1065 – 1076 in the *Louisiana Register* on May 20, 2005, is being reprinted to correct a typographical error and manifest errors in citations referring to sections that were amended in the Rule. This reprint corrects the text as it was amended in May 2005. LAC 33:XI.301.C was amended again in Rule OS065 in the *Louisiana Register* on October 20, 2005. That amendment is not reflected in this Editor's Note.

**Title 33**  
**ENVIRONMENTAL QUALITY**  
**Part XI. Underground Storage Tanks**

**Chapter 3. Registration Requirements, Standards, and Fee Schedule**

**§301. Registration Requirements**

A. Existing UST Systems

1. All owners of *existing UST systems* (as defined in LAC 33:XI.103) were required to register such systems by May 8, 1986, (USTs installed after that date were required to be registered within 30 days of bringing such tanks into use) on a form approved by the department. Tanks filled with a solid, inert material before January 1, 1974, are not required to be registered with the department.

A.2. – B.1.d. ...

2. All owners of new UST systems must ensure that the installer certifies on the registration form that the methods used to install the tanks and piping comply with the requirements of LAC 33:XI.303.A-B.4.a. Beginning January 20, 1992, registration forms shall include the name and department-issued certificate number of the individual exercising supervisory control over *installation-critical junctures* (as defined in LAC 33:XI.1303) of a UST system.

C. All UST system owners or operators shall comply with the following requirements.

1. Any person who sells a UST system shall so notify the Office of Environmental Services, Permits Division in writing within 30 days after the date of the transaction. A person selling a UST must also notify the person acquiring a regulated UST system of the owner's registration obligations under this Section.

2. Any person who acquires a UST system shall submit to the Office of Environmental Services, Permits Division an amended registration form within 30 days after the date of acquisition.

3. A current copy of the registration form must be kept on-site or at the nearest staffed facility.

4. No owner or operator shall allow a regulated substance to be placed into a new UST system that has not been registered.

AUTHORITY NOTE: Promulgated in accordance with R.S. 30:2001 et seq.

HISTORICAL NOTE: Promulgated by the Department of Environmental Quality, Office of Solid and Hazardous Waste, Underground Storage Tank Division, LR 11:1139 (December 1985), amended LR 16:614 (July 1990), LR 17:658 (July 1991), LR

18:727 (July 1992), LR 20:294 (March 1994), amended by the Office of Environmental Assessment, Environmental Planning Division, LR 26:2558 (November 2000), LR 28:475 (March 2002), amended by the Office of Environmental Assessment, Environmental Planning Division, LR 26:2558 (November 2000), amended by the Office of Environmental Assessment, LR 31:1066 (May 2005), repromulgated by the Office of the Secretary, Legal Affairs Division, LR 32:\*\* (March 2006).

## **Chapter 5. General Operating Requirements**

### **§509. Reporting and Recordkeeping**

A. Reporting. Owners and operators must submit the following information to the department:

1. registration forms (UST-REG-01 and 02) for all UST systems (LAC 33:XI.301), including certification of installation and verification of installer certification for new UST systems, in accordance with LAC 33:XI.303.B.4.b;

2. - 5. ...

B. Recordkeeping. Owners and operators must maintain the following information:

1. a corrosion expert's analysis of site corrosion potential if corrosion protection equipment is not used (LAC 33:XI.303.B.1.d and B.2.c);

2. documentation of operation of corrosion protection equipment (LAC 33:XI.503.BA.4);

3. documentation of UST system repairs (LAC 33:XI.507.BA.7);

4. documentation of recent compliance with release detection requirements (LAC 33:XI.705);

5. copies of the most current registration forms (UST-REG-01 and 02) filed with the department;

6. documentation of the type and construction of the tank, piping, leak detection equipment, and spill and overfill protection equipment; and

7. documentation of permanent closure, where applicable.

C. Availability and Maintenance of Records. Owners and operators must either keep the records required at the UST site and immediately available for the department's inspection, or keep them at a readily available alternative site and provide them to the department for inspection upon request.

AUTHORITY NOTE: Promulgated in accordance with R.S. 30:2001 et seq.

HISTORICAL NOTE: Promulgated by the Department of Environmental Quality, Office of Solid and Hazardous Waste, Underground Storage Tank Division, LR 16:614 (July 1990), amended LR 18:728 (July 1992), amended by the Office of Environmental Assessment, LR 31:1070 (May 2005), repromulgated by the Office of the Secretary, Legal Affairs Division, LR 32:\*\* (March 2006).

## **Chapter 13. Certification Requirements for Persons Who Install, Repair, or Close Underground Storage Tank Systems**

**§1313. UST Certification Board**

A. Composition. The administrative authority shall appoint seven members of a body to be known as the UST Certification Board. Members of the board shall be as follows:

1. the administrative authority or his or her designee;
2. a representative of the Louisiana Oil Marketers' Association;
3. a representative of the Mid-Continent Oil and Gas Association;
4. two representatives from within the UST contractor community;

and

5. two representatives from the Louisiana Association of Petroleum Equipment Contractors.

B. - F. ...

AUTHORITY NOTE: Promulgated in accordance with R.S. 30:2001 et seq.

HISTORICAL NOTE: Promulgated by the Department of Environmental Quality, Office of Solid and Hazardous Waste LR 16:614 (July 1990), amended LR 17:658 (July 1991), amended by the Office of Environmental Assessment, LR 31:1075 (May 2005), repromulgated by the Office of the Secretary, Legal Affairs Division, LR 32:\*\* (March 2006).