

Permitting Implementation Plan for the Bayou Bonfouca / Bayou Liberty (Subsegment 040905, 040906, 040907, 040908) Phase I DO TMDL

Phase I Permit Implementation

All TMDL, permitting, and enforcement activities will be conducted in accordance with the Clean Water Act, the Louisiana Environmental Regulatory Code, and applicable state laws.

1. New discharges of oxygen-demanding loads:

In general, LDEQ may not be able to permit additional discharges of oxygen-demanding loads. However, in the event that one the following requirements can be attained, LDEQ may permit a new discharge. The typical permit limits will be 5 mg/L BOD₅ / 2 mg/L NH₃ / 5 mg/L DO. Such new facilities may be required to submit an environmental impact assessment to LDEQ's permitting staff, which will conduct a thorough evaluation of the proposed facility based on environmental impacts, economic benefits, an analysis of alternatives, and other pertinent factors.

- a. The facility demonstrates that it will provide a significant load reduction of man-made oxygen-demanding constituents to the impaired watershed(s) serviced by the facility. The facility must also contribute to a reduction in the number of facilities discharging to the watershed(s). Facilities that may be considered for permits under this provision include, but are not limited to:
 - i. A facility that will provide improved sewage treatment to multiple subdivisions previously serviced by wastewater treatment plants that are incapable of treating to tertiary limits.
 - ii. A facility that will provide sewage collection and treatment to previously unsewered areas in which many of the sanitary discharges from permitted facilities and individual home treatment units were entering an impaired watershed. As a result, the facility would be expected to provide more efficient treatment to the wastewater and reduce the net loading of oxygen-demanding substances in the watershed.
- b. The facility demonstrates that its wastewater will not leave the facility or its property. Significant stormwater events do not apply to this provision. For the purpose of this provision, a significant stormwater event is defined as the 25 year, 24 hour rainfall event or its numerical equivalent, as defined by the Southern Regional Climate Center.

- i. Facilities that may be considered under this provision include, but are not limited to:
 - a. Effluent reduction systems that have been approved by the Louisiana Department of Health and Hospitals.
 - b. Wastewater treatment plants equipped with overland flow systems in which the effluent will not leave the facility.
 - c. Wastewater treatment plants equipped with holding ponds that will retain the effluent such that the effluent will not leave the facility.
- ii. LDEQ recognizes that some local governments are in the process of building or expanding regional sewage collection and treatment systems. In such areas, LDEQ may, on a limited basis, grant permits of limited durations to facilities that agree to tie into a regional collection and treatment system when it becomes available. LDEQ must have absolute assurance that the regional collection system will be available to the facility and the facility will connect to the regional collection system on or before the expiration date of the permit. Such assurance may include a formal agreement between the facility, the owner and operator of the regional wastewater treatment system, and LDEQ. The regional system must have the capacity to treat the additional wastewater. Such a permit may have a duration of less than five years or it may have a five year duration with interim permit limits. The permit will be written based on projected completion dates for the construction of the collection and treatment system. The facility will be required to cease all wastewater discharges to the Bayou Liberty watershed and transfer the discharge to the regional collection system once the permit or interim limits expire or the collection system is available to the facility, whichever comes first. If the permit or interim limits expire, but, due to unforeseen circumstances, the availability of the collection system has been temporarily delayed, the duration of the permit or interim limits may be extended. If the availability of the collection system has been indefinitely delayed, the facility may be required to cease all discharges to the Bayou Liberty watershed. Such facilities may resort to options covered in item 1.b.i. above.
- c. LDEQ reassesses Subsegments 040905, 040906, 040907, and 040908 (Bayou Liberty and Bayou Bonfouca). LDEQ determines that Subsegments 040905,

040906, 040907, and 040908 is meeting the appropriate DO criteria and designated uses.

2. Existing discharges of oxygen demanding loads:

The Phase I reductions for existing dischargers in the Bayou Liberty and Bayou Bonfouca Watersheds are presented in Tables 8 - 11. Existing facilities discovered to be discharging oxygen-demanding loads without LPDES permits as of the TMDL approval date are to be permitted in accordance with the limits established for existing facilities with permits. Unpermitted facilities that are newly activated or reactivated and discharging after the TMDL approval date may be subjected to enforcement actions and will be required to tie into regional collection and treatment systems, once those systems are available. Once the TMDL is approved, existing facilities may have up to 3 years from their next permit renewal date to meet the interim limits.

3. Nutrient monitoring (i.e., reporting for Total Nitrogen and Total Phosphorus) will be required for individual permits. Nutrient monitoring will be added to the general permit series (LAG530000, LAG540000, LAG560000, and LAG570000) upon the next scheduled renewal of each series.

Table 8. Interim Limits for 040905 Point Sources

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TYPE	OUT-FALL NO.	OUTFALL DESCRIPTION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
St. Tammany Parish Stormwater	108405/LAR041024	12/4/2012	Stormwater	N/A	Ditches to Bayou Liberty	Bayou Liberty	N/A	N/A		N/A	N/A	N/A	MS4 addressed in model and TMDL. This TMDL will not impose permit limits.
City of Slidell Stormwater	108410/LAR041015	12/4/2012	Stormwater	N/A	Ditches to Bayou Liberty	Bayou Liberty	N/A	N/A		N/A	N/A	N/A	MS4 addressed in model and TMDL. This TMDL will not impose permit limits.
Bayou Liberty Water Association	12830/LAG530716	12/1/2012	STP	001	Hwy 433 ditch to Bayou Liberty	Bayou Liberty	180	30		20	10	2	Modeled
Herron Wire Products Inc.	14221/LAG532809	12/1/2012	STP	001	Hwy 190 ditch to Bayou Liberty	Bayou Liberty	150	30		20	10	2	Modeled
Coast Waterworks Inc-The Meadows Subdivision	19119/LA0073148	7/1/2011	STP	001	Pipe to ditch to Bayou Liberty	Bayou Liberty	276000	10		10	2	2	Modeled
LA Water Service Inc-Oakmont Subdivision	19471/LAG570031	5/1/2014	STP	001	Ditch to Parish Canal to Bayou Liberty	Bayou Liberty	70600	10		10	2	2	Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIPTION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
Louisiana Water Service Inc-Huntwyck Village	19476/ LA0065714	9/1/2013	STP	001	Pipe to ditch to Bayou Liberty	Bayou Liberty	278000	10		10	5	2	Modeled
2315 Hwy 190 Building	27080/ LAG532824	12/1/2012	STP	001	Hwy 190 ditch to Bayou Liberty	Bayou Liberty	320	30		20	10	2	Modeled
Curtis Environmental Utilities Inc-Timber Ridge Subdivision	33837/ LAG570109	5/1/2014	STP	001	Ditch to Bayou Paquet	Bayou Paquet	44400	10		10	5	2	Modeled
The Southern District of Lutheran Church-Missouri Synod	42602/ LAG531992	12/1/2012	STP	001	Unnamed ditch to Bayou Liberty	Bayou Liberty	1600	30		10	10	2	Modeled
Royal Golf Club Inc	43097/ LAG530890	12/1/2012	STP	001	Local drainage to Bayou Liberty	Bayou Liberty	4340	30		10	10	2	Modeled
St Tammany Parish Police Jury-Thompson Road WWTP	43394/ LAG530650	12/1/2012	STP	001	Hwy 190 ditch to Bayou Liberty	Bayou Liberty	20	30		20	10	2	Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIP- TION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
Pit Stop #3	70933/ LAG531535	12/1/2012	STP	001	Hwy 190 ditch to Bayou Liberty	Bayou Liberty	1060	30		20	10	2	Modeled
Liberty Food Store	71168/ LAG531327	12/1/2012	STP	001	Bayou Liberty	Bayou Liberty	570	30		20	10	2	Modeled
Thompson Road Grocery Store #615	74116/ LAG532825	12/1/2012	STP	001	Hwy 190 ditch to Bayou Liberty	Bayou Liberty	80	30		20	10	2	Modeled
Cleco Power LLC- Slidell Service Center	83359/ LAG532103	12/1/2012	STP	001	Local drainage to Bayou Vincent	Bayou Vincent	200	30		20	10	2	Modeled
Butera Investments Inc-Lake Castle Private School	99225/ LAG541304	7/1/2013	STP	001	Unnamed ditch then to Bayou Liberty	Bayou Liberty	8700	30		10	10	2	Modeled
Louisiana Lumber Inc-Construction Project	107578/ LAG531777	12/1/2012	STP	001	Bayou Liberty	Bayou Liberty	400	30		20	10	2	Modeled
ABC Supply Co Inc	113210/ LAG531454	12/1/2012	STP	001	Hwy 190 ditch to Bayou Liberty	Bayou Liberty	140	30		20	10	2	Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIPTION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
G&S Bear Enterprises LLC	117778/ LAG531527	12/1/2012	STP	001	Hwy ditch to Bayou Liberty	Bayou Liberty	160	30		20	10	2	Modeled
Indian Hills RV Park	119158/ LAG541174	7/1/2013	STP	001	Hwy 190 ditch to Bayou Liberty	Bayou Liberty	7875	30		10	10	2	Modeled
Dollar General Store #6578	125413/ LAG531717	12/1/2012	STP	001	Hwy 190 ditch to Bayou Liberty	Bayou Liberty	120	30		20	10	2	Modeled
Hanna Brothers Extreme Motion Picture Catering	129058/ LAG531861	12/1/2012	STP	001	Local drainage to Bayou Liberty	Bayou Liberty	160	30		20	10	2	Modeled
Gause West Properties-Shopping Center for Faye Wagner	129831/ LAG531980	12/1/2012	STP	001	Ditch to Bayou Liberty	Bayou Liberty	1932	30		20	10	2	Modeled
Omni Storage VI LLC	140231/ LAG532056	8/15/2011	STP	001	Hwy 190 ditch to Bayou Liberty	Bayou Liberty	300	30		20	10	2	Modeled
Airgas Gulf States-WWTP	155400/ LAG532559	12/1/2012	STP	001	Local drainage to Bayou Liberty	Bayou Liberty	140	30		20	10	2	Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIP- TION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
CRS Properties LLC- Albers AC & Heating	157679/ LAG532786	12/1/2012	STP	001	Parish drainage to Bayou Liberty	Bayou Liberty	120	30		20	10	2	Modeled
Seventh-Day Adventist Church- WWTP	157724/ LAG532799	12/1/2012	STP	001	Hwy 190 ditch to Bayou Liberty	Bayou Liberty	1250	30		20	10	2	Modeled
Guardian Angels Learning Center II	157922/ LAG532862	12/1/2012	STP	001	Unnamed ditch to Bayou Liberty	Bayou Liberty	930	30		10	10	2	Modeled
All American Lodge Greatest in Elkdome	157925/ LAG532887	12/1/2012	STP	001	Unnamed ditch to Bayou Liberty	Bayou Liberty	1600	30		20	10	2	Modeled
RJD Contractors	157926/ LAG533686	12/1/2012	STP	001	Parish drainage to Bayou Bonfouca	Bayou Bonfouca	20	30		20	10	2	Modeled
2319 Hwy 190 Building	157927/ LAG532861	12/1/2012	STP	001	Hwy 190 ditch to Bayou Liberty	Bayou Liberty	40	30		20	10	2	Modeled
2317 Hwy 190 Building	157928/ LAG532860	12/1/2012	STP	001	Hwy 190 ditch to Bayou Liberty	Bayou Liberty	60	30		20	10	2	Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIPTION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
Assunta's Italian Restaurant of Slidell	157931/ LAG532904	12/1/2012	STP	001	Hwy 190 ditch to Bayou Liberty	Bayou Liberty	2900	30		20	10	2	Modeled
Lion Consulting Inc-Lion Multimedia & Consulting	157933/ LAG532890	12/1/2012	STP	001	Hwy 190 ditch to Bayou Liberty	Bayou Liberty	40	30		20	10	2	Modeled
Chill Rite	157934/ LAG532842	12/1/2012	STP	001	Hwy 190 ditch to Bayou Liberty	Bayou Liberty	220	30		20	10	2	Modeled
M & R File Service LLC-Russell & Michelle Bolotte	163444/ LAG533101	12/1/2012	STP	001	Parish ditch to unnamed tributary to Bayou Liberty	Bayou Liberty	60	30		20	10	2	Modeled
Fernandez-Zimmerle LLC	1609/ LAG533438	12/1/2012	STP	002	Into an unnamed tributary then to Bayou Liberty	Bayou Liberty	200	30		10	10	2	Not Modeled
Fernandez-Zimmerle LLC	1609/ LAG533438	12/1/2012	STP	003	Into an unnamed tributary then to Bayou Liberty	Bayou Liberty	400	30		10	10	2	Not Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIPTION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
Royale Gardens Homeowners Association-Royal Gardens Subdivision	19797/ LAG570046	5/1/2014	STP	001	Bayou Liberty	Bayou Liberty	35000	10		10	10	2	Not Modeled
Southern Pipe	168384/ LAG533350	12/1/2012	STP	001	By effluent pipe then into an unnamed ditch then into an unnamed canal then into Bayou Liberty	Bayou Liberty	80	30		10	10	2	Not Modeled
Carl Hodge Rental	169771/ LAG533393	12/1/2012	STP	001	Into an unnamed drainage ditch then into Bayou Bonfouca	Bayou Bonfouca	160	30		10	10	2	Not Modeled
Diversified Oil Field Services Inc	169801/ LA0125334	1/1/2016	STP	001	Into a roadside ditch then into Bayou Vincent then into Bayou Bonfouca	Bayou Vincent	400	30		10	10	2	Not Modeled

^a This TMDL was developed for critical low-flow conditions (7Q10). Therefore the WLAs for all stormwater discharges will be 0.0 lb/d under critical low flow conditions.

Table 9. Interim Limits for 040906 Point Sources

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TYPE	OUT-FALL NO.	OUTFALL DESCRIPTION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
St. Tammany Parish Stormwater	108405/ LAR041024	12/4/2012	Stormwater	N/A	Ditches to Bayou Liberty	Bayou Liberty	N/A	N/A		N/A	N/A	N/A	N/A	MS4 addressed in model and TMDL. This TMDL will not impose permit limits.
City of Slidell Stormwater	108410/ LAR041015	12/4/2012	Stormwater	N/A	Ditches to Bayou Liberty	Bayou Liberty	N/A	N/A		N/A	N/A	N/A	N/A	MS4 addressed in model and TMDL. This TMDL will not impose permit limits.
Acts 1 Tax Service Inc	40483/ LAG530841	12/1/2012	STP	001	Local drainage to Bayou Paquet	Bayou Paquet	60	30		75	20	10	5	Modeled
NC Investments LLC-Mom & Dad's Consignment Store	43141/ LAG532804	12/1/2012	STP	001	Ditch to Bayou Paquet	Bayou Paquet	40	30		50	20	10	2	Modeled
Waste Management of LA LLC-St. Tam Hauling Ctr	76287/ LA0078778	6/1/2010	STP	001	Hwy 190 ditch to Bayou Paquet	Bayou Paquet	500	30		625	20	10	2	Modeled
A-1 Remodeling & Building Inc	93349/ LAG531273	12/1/2012	STP	001	Hwy 190 ditch to Bayou Liberty	Bayou Liberty	200	30		250	20	10	2	Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TYPE	OUT-FALL NO.	OUTFALL DESCRIP- TION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
Bayou Liberty Marina	94269/ LAG531330	12/1/2012	STP	001	Ditch to Bayou Liberty	Bayou Liberty	20	30		25	20	10	2	Modeled
A Bonfouca Marina	114175/ LAG531465	12/1/2012	STP	001	Directly to Bayou Liberty then into Bayou Bonfouca then into Lake Pontchartrain	Bayou Liberty	860	30		1,075	20	10	2	Modeled
Thompson Road Baptist Church- WWTP	138188/ LAG532165	12/1/2012	STP	001	Hwy 433 ditch to Bayou Liberty	Bayou Liberty	800	30		1,000	20	10	2	Modeled
Accurate Alignment	151364/ LAG470244	9/1/2014	STP	001	Ditch to Bayou Paquet	Bayou Paquet	20	30		25	20	10	2	Modeled
All American Cargo Elevators LLC WWTP	157614/ LAG532770	12/1/2012	STP	001	Highway 190 ditch to Bayou Liberty	Bayou Liberty	60	30		75	20	10	2	Modeled
St. Genevieve Catholic Church- WWTP	157725/ LAG532800	12/1/2012	STP	001	Pipe to Bayou Liberty	Bayou Liberty	3000	30		3,750	20	10	2	Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TYPE	OUT-FALL NO.	OUTFALL DESCRIPTION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
Broadway Inc: K-Bar-B Youth Ranch-Cabins & Admin Complex	164343/ LAG533161	12/1/2012	STP	001	Hwy 190 ditch to Bayou Paquet	Bayou Paquet	2300	30		2,875	20	10	2	Modeled
R&D Automotive	24329/ LAG470270	9/1/2014	STP	001	Into an unnamed drainage ditch then into unnamed parish drainage then into Bayou Liberty	Bayou Liberty	500	30		N/A	10	10	2	Not Modeled
Timberland Trailer Park LLC	98284/ LAG531573	12/1/2012	STP	001	To local drainage then to W15 Canal then to Doubloon Bayou then to Fritchie Marsh	W15 Canal	4500	30		N/A	10	10	2	Not Modeled
Mayfield Elementary School	161289/ LAG541758	7/1/2013	STP	001	Pipe then to ditch then to Bayou Bonfouca	Bayou Bonfouca	14250	10		N/A	10	10	2	Not Modeled

Table 10. Interim Limits for 040907 Point Sources

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TYPE	OUT-FALL NO.	OUTFALL DESCRIPTION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
St. Tammany Parish Stormwater	108405/ LAR041024	12/4/2012	Stormwater	N/A	Ditches to Bayou Bonfouca	Bayou Bonfouca	N/A	N/A		N/A	N/A	N/A	N/A	MS4 addressed in model and TMDL. This TMDL will not impose permit limits.
City of Slidell Stormwater	108410/ LAR041015	12/4/2012	Stormwater	N/A	Ditches to Bayou Bonfouca	Bayou Bonfouca	N/A	N/A		N/A	N/A	N/A	N/A	MS4 addressed in model and TMDL. This TMDL will not impose permit limits.
ExxonMobil Oil Corp #51367	13400/ LAG530198	12/1/2012	STP	001	Ditch to Bayou Vincent	Bayou Vincent	2500	30		3,125	10	10	2	Modeled
Sunbelt Innovative Plastics Inc STP	17609/ LA0090409	2/1/2016	STP	001	Local drainage to Bayou Liberty	Bayou Liberty	2500	30		3,125	10	10	2	Modeled
Stones Throw Apartments	17938/ LAG570066	5/1/2014	STP	001	Pipe to Bayou Vincent	Bayou Vincent	19200	10		24,000	10	10	2	Modeled
Eagle Lake Mobile Home Park	19785/ LAG570120	5/1/2014	STP	001	Unnamed ditch to Bayou Vincent to Bayou Bonfouca	Bayou Vincent	63000	10		78,750	10	10	2	Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIP-TION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L		GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	
John's Automotive Machine Shop Inc	24697/ LAG530274	12/1/2012	STP	001	Roadside ditch to Hwy 11 ditch to Bayou Vincent	Bayou Vincent	40	30		50	10	10	2	Modeled
Northshore Chemical LLC	41239/ LA0122459	4/1/2012	STP	001	Local drainage to Bayou Vincent	Bayou Vincent	55	30		69	10	10	2	Modeled
Factory Direct Furniture	41484/ LAG530200	12/1/2012	STP	001	Ditch to Bayou Vincent	Bayou Vincent	40	30		50	10	10	2	Modeled
Ernest Walder Sr	41768/ LAG530736	12/1/2012	STP	001	Local drainage to Bayou Vincent	Bayou Vincent	360	30		450	10	10	2	Modeled
LCR-M-Plumbing Supply	41993/ LAG530703	12/1/2012	STP	001	Local drainage to Bayou Vincent	Bayou Vincent	120	30		150	10	10	2	Modeled
J&K Management LLC	41995/ LAG532382	12/1/2012	STP	001	Directly to Bayou Vincent	Bayou Vincent	180	30		225	10	10	2	Modeled
New Life Ministries	42622/ LAG530943	12/1/2012	STP	001	Local drainage to Bayou Liberty	Bayou Liberty	490	30		613	10	10	2	Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIP-TION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L		GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	
Nu-Lite Electrical Wholesalers	42686/ LAG530397	12/1/2012	STP	001	I-12 Service Road Ditch to unnamed ditch to Bayou Bonfouca	Bayou Bonfouca	80	30		100	10	10	2	Modeled
Piney Ridge Mobile Home Park LLC	42841/ LAG540932	7/1/2013	STP	001	Ditch to Bayou Vincent	Bayou Vincent	9300	30		11,625	10	10	2	Modeled
S&H Good Eats Café	42865/ LAG533440	12/1/2012	STP	001	Hwy 190 Ditch to Bayou Vincent	Bayou Vincent	490	30		613	10	10	2	Modeled
Coastal Property Holdings LLC-Shady Pines Mobile Home Park	43212/ LAG540642	7/1/2013	STP	001	Roadside ditch to Bayou Bonfouca	Bayou Bonfouca	10500	30		13,125	10	10	2	Modeled
Skater's Paradise II, Inc.	43242/ LAG530811	12/1/2012	STP	001	Hwy 190 ditch to Bayou Bonfouca	Bayou Bonfouca	540	30		675	10	10	2	Modeled
South Seas Chinese Restaurant	43274/ LAG530987	12/1/2012	STP	001	Ditch to Bayou Vincent	Bayou Vincent	1950	30		2,438	10	10	2	Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIP-TION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
Ellis Recycling	43316/ LAG480553	8/1/2011	STP	001	Industrial Dr ditch to Bayou Vincent	Bayou Vincent	120	30		150	10	10	2	Modeled
St Tammany Parish School Board-Slidell Support Facility	43403/ LAG530531	12/1/2012	STP	001	Ditch to Bayou Vincent	Bayou Vincent	100	30		125	10	10	2	Modeled
Wadleigh Industries Inc-Offshore Equipment Solutions	52386/ LA0109495	5/1/2015	STP	001	Ditches to Bayou Vincent	Bayou Vincent	800	30		1,000	10	10	2	Modeled
Blue Bell Creameries Inc	68576/ LAG532783	12/1/2012	STP	001	Ditch to Bayou Bonfouca	Bayou Bonfouca	780	30		975	20	10	2	Modeled
I-12 Shell	71531/ LAG531734	12/1/2012	STP	001	Local drainage to Bayou Bonfouca	Bayou Bonfouca	160	30		200	10	10	2	Modeled
Jubilee #4815	74005/ LAG480587	8/1/2011	STP	001	Local drainage to Bayou Vincent	Bayou Vincent	1700	30		2,125	10	10	2	Modeled
Charter Communications	96374/ LAG531494	12/1/2012	STP	001	Roadside ditch to Bayou Vincent	Bayou Vincent	120	30		150	10	10	2	Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIP-TION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L		GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	
Adams Mobile Home Park	98300/ LAG541621	12/1/2012	STP	001	Local drainage to Bayou Vincent	Bayou Vincent	2100	30		2,625	10	10	2	Modeled
Tymeless Flooring Inc	99281/ LAG531318	12/1/2012	STP	001	Hwy 190 ditch to Bayou Bonfouca	Bayou Bonfouca	100	30		125	10	10	2	Modeled
Baker Sales Inc-Baker Sales Warehouse	103353/ LAG531763	12/1/2012	STP	001	Ditch to Bayou Liberty	Bayou Liberty	40	30		50	10	10	2	Modeled
Johnson Apartments	117172/ LAG531511	12/1/2012	STP	001	Local drainage to Bayou Vincent	Bayou Vincent	800	30		1,000	10	10	2	Modeled
Beau's Air Conditioning & Heating LLC	117735/ LAG531519	12/1/2012	STP	001	Local drainage to Hwy 190 ditch to unnamed canal to Bayou Liberty	Bayou Liberty	140	30		175	10	10	2	Modeled
Venson Harold Seal Apartments	117751/ LAG531526	12/1/2012	STP	001	To a pond to Bayou Vincent	Bayou Vincent	750	30		938	10	10	2	Modeled
Acadiana Stor-N-Lock	120264/ LAG531938	12/1/2012	STP	001	Ditch to Bayou Vincent	Bayou Vincent	40	30		50	10	10	2	Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIP-TION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L		GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	
CalWes Properties LLC-CalWes Center	126385/ LAG532174	12/1/2012	STP	001	Hwy 190 ditch to Bayou Bonfouca	Bayou Bonfouca	4145	30		5181	20	10	2	Modeled
Peace Lutheran Church-RV Units	133232/ LAG532329	12/1/2012	STP	001	Hwy ditch to Bayou Bonfouca	Bayou Bonfouca	2370	30		2693	10	10	2	Modeled
Jolly Investments LLC-Jolly Investments Apartments	133963/ LAG541455	7/1/2013	STP	001	Ditch to Bayou Bonfouca	Bayou Bonfouca	5700	30		7125	10	10	2	Modeled
United Medical Care Walk In Clinic	134229/ LAG532037	12/1/2012	STP	001	Ditch to Bayou Vincent	Bayou Vincent	200	30		250	20	10	2	Modeled
Good Shepherd Lutheran Church	148472/ LAG532580	12/1/2012	STP	001	Ditch to Bayou Bonfouca	Bayou Bonfouca	1100	30		1375	10	10	2	Modeled
RDG Properties- Platform Crane-Bldg 2	149820/ LAG532253	12/1/2012	STP	001	Local drainage to Bayou Vincent	Bayou Vincent	600	30		750	10	10	2	Modeled
GBR Properties Inc- Advance Auto	151898/ LAG532293	12/1/2012	STP	001	Hwy 190 ditch to canal to Bayou Liberty	Bayou Liberty	100	30		125	20	10	2	Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIP-TION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L		GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	
RDG Properties-SE LA Veterans Healthcare & Omni Eng	161936/ LAG530000	12/1/2012	STP	001	Pipe to local drainage to Bayou Vincent	Bayou Vincent	600	30		750	10	10	2	Modeled
St. Tammany Brake Tag Center-St Tammany Wholesale	165431/ LAG470290	9/1/2014	STP	001	Pipe to Hwy 190 ditch to Bayou Bonfouca	Bayou Bonfouca	40	30		50	10	10	2	Modeled
Cut-Rite, Inc. Cut Rite/Northshore Driveline	13288/ LAG533518	12/1/2012	STP	001	Local drainage then to Bayou Liberty	Bayou Liberty	500	30		N/A	10	10	2	Not Modeled
Advantage Tire & Wheel	14744/ LAG470293	9/1/2014	STP	001	Unnamed ditch then to Bayou Liberty	Bayou Liberty	1500	30		N/A	10	10	2	Not Modeled
Western International Gas & Cylinder Inc-Slidell Facility	20072/ LA0096334	2/1/2016	STP	001	Pipe to an unnamed ditch then into an unnamed canal then into Bayou Liberty	Bayou Liberty	4480	30		N/A	10	10	2	Not Modeled
Jung's Automotive, Inc	25610/ LAG470303	9/1/2014	STP	001	To local drainage then to Bayou Liberty	Bayou Liberty	300	30		N/A	10	10	2	Not Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIPTION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L		GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	
CM Auto Repair Inc	27558/ LAG470149	9/1/2014	STP	001	Open ditch to US Highway 190W then to ditch above Hwy 190 then to Bayou Paquet	Bayou Paquet	500	30		N/A	10	10	2	Not Modeled
Randall A Evans DDS LLC	34988/ LAG533431	12/1/2012	STP	001	Local drainage then to Bayou Bonfouca	Bayou Bonfouca	500	30		N/A	10	10	2	Not Modeled
Rowland Duffour Clinic	36461/ LAG533501	12/1/2012	STP	001	By effluent pipe then into an unnamed ditch then into Bayou Paquet	Bayou Paquet	500	30		N/A	10	10	2	Not Modeled, No State Permit
Brown's Village Road Sand Pit	40412/ LAG490031	2/1/2015	STP	001	Local drainage then to Bayou Bonfouca	Bayou Bonfouca	100	30		N/A	10	10	2	Not Modeled
Capitol Steel Inc-Slidell	42161/ LAG530763	12/1/2012	STP	001	By effluent pipe then into parish drainage ditch then to Bayou Bonfouca	Bayou Bonfouca	1400	30		N/A	10	10	2	Not Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIPTION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
Slidell Welding Service Inc	43249/ LAG530660	12/1/2012	STP	001	Effluent pipe then to State Hwy 190 (Gause West Ditch) then into St. Tammany Ditch then to Bayou Bonfouca	Bayou Bonfouca	300	30		N/A	10	10	2	Not Modeled
Slidell Welding Service Inc	43249/ LAG530660	12/1/2012	STP	001	Effluent pipe then to State Hwy 190 (Gause West Ditch) then into St. Tammany Ditch then to Bayou Bonfouca	Bayou Bonfouca	100	30		N/A	10	10	2	Not Modeled
Circle K #1689	75145/ LAG533633	12/1/2012	STP	001	Into local drainage then into Bayou Bonfouca	Bayou Bonfouca	1000	30		N/A	10	10	2	Not Modeled
Eagle LLC-Eagle Carwash	82445/ LAG750317	3/15/2014	STP	001	Local drainage then to Bayou Vincent	Bayou Vincent	500	30		N/A	10	10	2	Not Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIPTION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
Terminix-Home Estates Drive Office Project	90273/ LAG750602	3/15/2014	STP	001	Unnamed ditch then to Gum Bayou	Gum Bayou	320	30		N/A	10	10	2	Not Modeled
Coastal Marine Contractors LLC (CMC) - Main Yard - Ship & Barge Repair Facility	167032/ LA0124877	9/1/2015	STP	001	Bayou Bonfouca	Bayou Bonfouca	300	30		N/A	10	10	2	Not Modeled
Manuel Darby Property	167139/ LAG533313	12/1/2012	STP	001	By effluent pipe, then into Hwy 190 ditch then into Bayou Bonfouca	Bayou Bonfouca	490	30		N/A	10	10	2	Not Modeled
Guardian Angel Learning Center	167920/ LAG533301	12/1/2012	STP	001	Parish drainage, then into Bayou Bonfouca	Bayou Bonfouca	510	30		N/A	10	10	2	Not Modeled
Slidell Masjid of Al-Islam	167945/ LAG533308	12/1/2012	STP	001	Parish drainage ditch, then into Bayou Vincent, then into Bayou Bonfouca	Bayou Vincent	15	30		N/A	10	10	2	Not Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIPTION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
Ozone Aggregates	168041/ LAG533333	12/1/2012	STP	001	Effluent pipe to a drainage ditch then to Bonfouca Bayou, then to Lake Pontchartrain	Bayou Bonfouca	80	30		N/A	10	10	2	Not Modeled
Arian Nursery & Preschool	168045/ LAG533353	12/1/2012	STP	001	By effluent pipe then to unnamed ditch then to Bayou Bonfouca	Bayou Bonfouca	950	30		N/A	10	10	2	Not Modeled
Romar Services Inc-Warehouse	168139/ LAG533302	12/1/2012	STP	001	Unnamed ditch then into Bayou Bonfouca	Bayou Bonfouca	80	30		N/A	10	10	2	Not Modeled
Carolyn Draperies	168371/ LAG533343	12/1/2012	STP	001	Local drainage then to Bayou Bonfouca	Bayou Bonfouca	20	30		N/A	10	10	2	Not Modeled
Pentecost Missionary Baptist Church of Slidell	169553/ LAG533559	12/1/2012	STP	001	By effluent pipe then into a parish drainage ditch then into Bayou Bonfouca then into Lake Pontchartrain	Bayou Bonfouca	1290	30		N/A	10	10	2	Not Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIPTION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
Honaker Funeral Home & Cemeteries Inc-Honaker Funeral Home Forest Lawn Cemetery	169689/ LAG533399	12/1/2012	STP	001	Treatment plant effluent pipe then into State Hwy 190 (W Gause Ditch) then to St. Tammany ditch then into Bayou Bonfouca	Bayou Bonfouca	1800	30		N/A	10	10	2	Not Modeled
Coco's Auto/Truck Repair	169692/ LAG470301	9/1/2014	STP	005	To local drainage then to Bayou Liberty	Bayou Liberty	300	30		N/A	10	10	2	Not Modeled
Sparrows Offshore LLC	169789/ LA0125351	1/1/2016	STP	001	By effluent pipe then into Hwy 190 ditch then into Bayou Bonfouca	Bayou Bonfouca	500	30		N/A	10	10	2	Not Modeled
James & Leonard Brown Commercial Property	169799/ LAG533457	12/1/2012	STP	001	Into an unnamed drainage ditch then into Bayou Vincent then into Bayou Bonfouca	Bayou Vincent	500	30		N/A	10	10	2	Not Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TTYPE	OUT-FALL NO.	OUTFALL DESCRIPTION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L		GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	
RPM Pizza LLC	170122/ LAG533147	12/1/2012	STP	001	Into parish drainage then into Bayou Bonfouca	Bayou Bonfouca	1500	30		N/A	10	10	2	Not Modeled
Lee's Hamburgers	170398/ LAG533422	12/1/2012	STP	001	Unnamed ditches then into Lee St. Pumping Station then into Bayou Bonfouca	Bayou Bonfouca	1500	30		N/A	10	10	2	Not Modeled
Flowers Baking Co of New Orleans LLC	170858/ LAG533465	12/1/2012	STP	001	To Hwy 433 ditch then to Bayou Bonfouca	Bayou Bonfouca	500	30		N/A	10	10	2	Not Modeled
John L's Plumbing	171511/ LAG533505	12/1/2012	STP	001	Pipe then into Bayou Bonfouca	Bayou Bonfouca	900	30		N/A	10	10	2	Not Modeled

Table 11. Interim Limits for 040908 Point Sources

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TYPE	OUT-FALL NO.	OUTFALL DESCRIPTION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
St. Tammany Parish Stormwater	108405/ LAR041024	12/4/2012	Stormwater	N/A	Ditches to Bayou Bonfouca	Bayou Bonfouca	N/A	N/A		N/A	N/A	N/A	N/A	MS4 addressed in model and TMDL. This TMDL will not impose permit limits.
City of Slidell Stormwater	108410/ LAR041015	12/4/2012	Stormwater	N/A	Ditches to Bayou Bonfouca	Bayou Bonfouca	N/A	N/A		N/A	N/A	N/A	N/A	MS4 addressed in model and TMDL. This TMDL will not impose permit limits.
Coin du Lestin Subdivision	19211/ LAG570065	5/1/2014	STP	001	Pipe to Bayou Bonfouca	Bayou Bonfouca	80000	10		100,000	10	5	2	Modeled
Pearl River Navigation Inc	24247/ LA0109461	3/1/2011	STP	001	Direct discharge to Bayou Bonfouca	Bayou Bonfouca	3500	30		4375	20	10	2	Modeled
Acadian Gardens Condominium Association	40443/ LAG540085	7/1/2013	STP	001	To an unnamed ditch then to Bayou Bonfouca	Bayou Bonfouca	7500	30		9375	20	10	2	Modeled
St. Tammany Parish-Oakwood Estates STP	43203/ LAG570166	5/1/2014	STP	001	Ditch to Bayou Bonfouca	Bayou Bonfouca	12400	10		15,500	10	5	2	Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TYPE	OUT-FALL NO.	OUTFALL DESCRIP- TION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L		GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	
J&J Auto Brokers	104963/ LAG470178	9/1/2014	STP	001	Unnamed ditch to Bayou Liberty	Bayou Liberty	40	30		50	20	10	2	Modeled
Slidell Marine Inc	124476/ LAG532176	12/1/2012	STP	001	Direct to Bayou Bonfouca	Bayou Bonfouca	3700	30		4625	20	10	2	Modeled
Carroll Road Building-STP Construction	124764/ LAG531773	12/1/2012	STP	001	Ditch to Bayou Bonfouca	Bayou Bonfouca	800	30		1,000	20	10	2	Modeled
JGILS-J&D Investments	125337/ LAG531786	12/1/2012	STP	001	Ditches to Bayou Bonfouca	Bayou Bonfouca	160	30		200	20	10	2	Modeled
ARC Mechanical Contractors Inc	138813/ LAG532075	12/1/2012	STP	001	Ditch to Bayou Bonfouca	Bayou Bonfouca	100	30		125	20	10	2	Modeled
Slidell Easy Pay Tire Store	5931/ LAG470233	9/1/2014	STP	001	Unnamed ditch then to Bayou Liberty	Bayou Liberty	100	30		N/A	20	10	2	Not Modeled

FACILITY	AI NO./ PERMIT NO.	PERMIT EXP DATE (MM/DD/YY)	FACILITY TYPE	OUT-FALL NO.	OUTFALL DESCRIP- TION	RECEIVING WATER	CURRENT EXPECTED FLOW	CURRENT MONTHLY AVERAGE CONCENTRATION LIMITS		TMDL FLOW	INTERIM PHASE I MONTHLY AVERAGE CONCENTRATION LIMITS			MODELING COMMENTS
							GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	GPD	BOD5/ CBOD5, mg/L	NH ₃ -N, mg/L	DO, mg/L	
Brian Harris Autoplex	118103/ LAG470186	9/1/2014	STP	001	Pipe to the Sunset Drive roadside ditch then to the US Hwy 190 West roadside ditch then to Bayou Bonfouca	Bayou Bonfouca	120	30		N/A	20	10	2	Not Modeled
Casadaban Marine Services	143036/ LAG533292	12/1/2012	STP	001	Local drainage then to Bayou Vincent	Bayou Vincent	500	30		N/A	20	10	2	Not Modeled